From: Michael Lavender
Sent: 21 June 2019 15:28
To: Marie O'Keeffe
Subject: Re: 45 South Street - 0735/19

The existing boundary fence/wall will act as a barrier if the units are lowered, further reducing the noise. As long as the top of the unit is no higher than 6ft this should be ok. Noise levels from the units are not excessive and I don't expect them to be audible in the neighbouring garden.

Michael

On Fri, 21 Jun 2019, 15:13 Marie O'Keeffe, <marie.o'keeffe@adur-worthing.gov.uk> wrote:

> Hi Michael
>
> Thanks for your comments of 6th June. Neighbour to rear, 6 Ingleside Cresc, is worried about noise from these condensers? Presumably you don't think there is a potential for noise nuisance?
>
> How much lower down the wall would you like the boxes. Just above door height?
>
> M.
>
> --
>
> **Marie O'Keeffe**
> Senior Planning Officer - Part Time, Adur & Worthing Councils
> Phone: 01903 221425
> Email: marie.o'keeffe@adur-worthing.gov.uk
> Website: http://www.adur-worthing.gov.uk
> Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA