Planning Development Control
Adur District Council
Civic Centre
Ham Road
Shoreham-by Sea
West Sussex
BN43 6PR



15th September 2009

Att: Carlos Hone

Dear Sirs

Ref: ADC/0286/09
Site: 184 Downside, Shoreham-by-Sea, West Sussex. BN43 6HD
Proposal: Loft Conversion with Front Dormer.

With reference to our telephone conversations, I have calculated the additional volume added by the dormers and side gable as follows:-
1. Front Dormer 9.6m3
2. Rear Dormers 14.9m3 and 11.1m3
3. Gable End 12m3
Total added volume 47.6m3
I understand that permitted development allows for up to 50m3 to be added, so this falls within the allowable limits
I hope that this will now enable you to look favourably at the application.

Yours faithfully

[redacted]

P Davey
Tel: 07743 809264
Email: pdavey@gtainterior.com