**From:** Ken Argent
**Sent:** 28 February 2017 11:44
**To:** Peter Barnett
**Subject:** Re: AWDM/01031/17 - Tesco Holmbush hand car wash and valeting centre

**Flag Status:** Flagged

Peter,

I have looked over the application, Holmbush Centre lies in flood zone 1 and suffers surface water flooding along the access road from the south.

The proposals will cause no flooding issues, but must be conditioned such that waste water is disposed of to the Foul Water system, which is what is proposed.

Regards

**Ken Argent**
Engineer, Adur & Worthing Councils
Phone: 01903221374
Email: ken.argent@adur-worthing.gov.uk
Website: www.adur-worthing.gov.uk
Address: Engineering Team, Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA



On 28 February 2017 at 09:48, Peter Barnett <peter.barnett@adur-worthing.gov.uk> wrote:

> Ken
>
> You haven't been consulted on this one for some reason. I assume you want to comment?
>
> Thanks
>
> Peter
>
> **Peter Barnett**
> Principal Planning Officer, Adur & Worthing Councils
> Phone: 01903 221310
> Email: peter.barnett@adur-worthing.gov.uk
> Website: http://www.adur-worthing.gov.uk
> Address: Development Management, Portland House, 44 Richmond Road, Worthing, BN11 1HS

