This email and any associated files is intended only for use by the individual or entity to which it is addressed and may contain information that is confidential, subject to copyright or constitutes a trade secret. If you are not the intended recipient you are hereby notified that any dissemination, copying or distribution of this message or files associated with it is strictly prohibited. If you have received this message in error please notify us immediately.

From: Stephen Cantwell <stephen.cantwell@adur-worthing.gov.uk>
Sent: 09 November 2023 10:23
To: Richard Abraham <Richard.Abraham@hgp-architects.co.uk>
Subject: Fwd: Lighting Questions

Hi Richard,

Regarding lighting a few Q's . Pl call if quicker to discuss

the proposal is for wall mounted bulk-heads denoted FE as below. Some lighting is denoted M with an annotated Bollard to be confirmed.

- Is there a detail of bollards yet - how tall and ideally at the southern side of podiums, minimising light spill towards the River. Hockey stick types facing north along this edge would minimise this
Proposal is to use KSR1198 colour switchable 970mm tall 20W LED Bollards as used on previous Hyde schemes (e.g. Coldean) - SEE DATASHEET ATTACHED TYPE M

- The roof plan for electrical works (last image below) mainly shows PVs but some details e.g the circled DE may be lighting - can you advise whether any are lighting and how mounted if so (I suspect v low risk of any impact if below parapet)
Proposal is to use Ansell ADLED2/WV/CCT/M3 14W LED bulkheads with emergency conversion. These will be mounted to a ballasted frame, similar to image attached - ALSO SEE DATASHEET ATTACHED TYPE DE

- None of the lighting on the site appears to be pole mounted but pl can you confirm this?
This is correct

- Can you confirm whether the bulk-heads on riverside path project over the path - ideally not, as this may impinge the clear width needed for shared cycles-pedestrians.
We propose to change the Type FE fittings on the riverside path wall to a new type SE as weblink below
https://qvis.co.uk/lighting/ec-hm-18

- Will the (connection?) boxes mentioned in the image of the riveride lighting immediately below , be visible or concealed within the landscaping e.g. concealed below shingle? If visible, what do they look like/ size?
Detail to be advised, however we will ensure the junction boxes are not visible from the riverside path (& note as such on next issue of our boardwalk layout)

Regards
Stephen

