From: Wendy Anderson <wendy.anderson@adur-worthing.gov.uk>
Sent: 04 December 2024 11:47:25 UTC+00:00
To: "Jo Morin" <jo.morin@adur-worthing.gov.uk>
Subject: Planning application AWDM/1436/24, 303 Tarring Road Worthing

Hi Jo,

Having viewed the application and plans via the online portal, the following observation is made, which will require remedial action:

The kitchenette directly communicates with the water closet room. As the kitchenette is a food room, a ventilated lobby will be needed to hygienically separate the two areas.

Thanks, Wendy.

Wendy Anderson
Senior Environmental Health Officer, Public Health & Regulation
Adur & Worthing Councils
Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA
www.adur-worthing.gov.uk



