From: Joanne Lewis
Sent: 15 August 2018 12:08
To: Eve Hearsey
Subject: 57 - 59 Test Road Sompting West Sussex BN15 0EN

AWDM/0998/18
57 - 59 Test Road Sompting West Sussex BN15 0EN

I refer to the above planning application and have concerns about noise from the proposed plant affecting the residential amenity of nearby properties, including the flats above the shop. I would therefore recommend the following condition;

Provide a scheme which shall be submitted to and approved by the local planning authority for attenuating all external fixed plant. The scheme shall have regard to the principles of BS4142: 2014 and ensure there is no detrimental impact to the amenity of the flats above and the nearest residential dwellings on Hamble Road. A test to demonstrate compliance with the scheme shall be undertaken within 1 month of the scheme being implemented. All plant shall be maintained in accordance with manufacturers guidance and any future plant shall also meet the specified levels within the approved scheme.

Joanne

Joanne Lewis
Environmental Health Technician, Adur & Worthing Councils
Phone: 01273 263113
Email: joanne.lewis@adur-worthing.gov.uk
Website: www.adur-worthing.gov.uk
Portland House, 44 Richmond Road, Worthing, West Sussex, BN11 1HS

