From: Michael Lavender
Sent: 19 December 2016 10:56
To: Peter Barnett
Subject: Re: Gym Noise Assessment for Application AWDM/1480/16, Brighton Rd, Shoreham.

Flag Status: Flagged

Hi Peter,

I am happy with the acoustic report.

I would suggest that you condition all the Acoustician's recommendations, particularly for the ceiling improvements and for the control of amplified music. The maximum sound level could be controlled through a sound limiter. It depends how tight you want the condition, but I am happy to discuss.


The actual gym is not underneath the residential properties but they will share a party wall. I would recommend that quiet gym equipment such as rowing machines and cross trainers etc are positioned towards to party wall and machinery that could clank and loose weight training positions are to the East of the room away from the party wall.

Michael

On 14 December 2016 at 11:41, Peter Barnett <peter.barnett@adur-worthing.gov.uk> wrote:

> Michael
>
> Can I please have your comments on the noise assessment?
>
> Thanks
>
> Peter

Peter Barnett
Principal Planning Officer, Adur & Worthing Councils
Phone: 01903 221310
Email: peter.barnett@adur-worthing.gov.uk
Website: http://www.adur-worthing.gov.uk
Address: Development Management, Portland House, 44 Richmond Road, Worthing, BN11 1HS



---------- Forwarded message ----------
From: **Peter Barnett** <peter.barnett@adur-worthing.gov.uk>
Date: 5 December 2016 at 08:28
Subject: Fwd: Gym Noise Assessment for Application AWDM/1480/16, Brighton Rd, Shoreham.
To: Michael Lavender <michael.lavender@adur-worthing.gov.uk>


Michael

Please can I have your comments on the attached noise assessment?

thanks

Peter

Peter Barnett
Principal Planning Officer, Adur & Worthing Councils
Phone: 01903 221310
Email: peter.barnett@adur-worthing.gov.uk
Website: http://www.adur-worthing.gov.uk
Address: Development Management, Portland House, 44 Richmond Road, Worthing, BN11 1HS



---------- Forwarded message ----------
From: **Chris Kraszewski** <chris@caratscafebar.com>
Date: 2 December 2016 at 12:47
Subject: Fwd: Gym Noise Assessment for Application AWDM/1480/16.
To: peter.barnett@adur-worthing.gov.uk
Cc: Robert Saunders X <Rob@rsparchitects.co.uk>

Hi Peter

Please see below report from Acoustic Associates Sussex and transport report

This should now complete the request for application AWDM/1480/16.

The completion date is set for Friday the 9th December. At what point can you advise we can start marketing. At this stage it we will only be using the window frontage on the site itself..

Thanks for your assistance and look forward to hearing from you soon.

Kind regards

Chris Kraszewski

chris@caratscafebar.com
Tel : 01273 430924
Mobile : 07720 037389

This email and any files transmitted with it are strictly confidential and intended solely for the use of the individual or entity to whom they are addressed. If you have received this email in error, please notify us by replying to the sender, and immediately delete this email from your system. Please note that in these circumstances, the use, disclosure, distribution or copying of this information is strictly prohibited. We apologise for any inconvenience that may have been caused to you. We cannot accept any responsibility for the accuracy or completeness of this message as it has been transmitted over a public network. If you suspect that the message may have been intercepted or amended, please contact the sender as soon as possible.

Begin forwarded message:

From: Simon Barrett <simonbarrett@aasussex.co.uk>
Subject: Gym Noise Assessment
Date: 2 December 2016 at 10:33:38 GMT
To: Chris Kraszewski <chris@caratscafebar.com>
Cc: Sue Shelley <sueshelley@aasussex.co.uk>

Dear Chris,

Please find attached the noise assessment report for the proposed gym at 394 – 398 Brighton Road, Shoreham by Sea.

Unfortunately I do not have the contact details for Peter Barrett at Planning so will not be able to forward it to him.

Kind Regards,

Simon Barrett BSc(Hons) MSc MIOA
Acoustic Associates Sussex Ltd.
& Sound Solutions Products Ltd.

Tel: +44 (0)1273 455074
Email (Direct): simonbarrett@aasussex.co.uk **Email (General):** info@aasussex.co.uk
Web: http://www.aasussex.co.uk
Web: http://www.sndsol.co.uk

Address: Unit 8 Highdown House, Shoreham Airport, Shoreham-by-Sea, West Sussex, BN43 5PB.

DISCLAIMER: The information in this email including any attached files is confidential and intended for the recipient(s) only. If you have received this email in error, please delete it. Acoustic Associates Sussex Ltd cannot be held liable for any misuse of the email and/or its related content.

While all emails sent are scanned for viruses before sending, it remains the responsibility of the recipient(s) to scan their incoming emails for viruses before downloading and/or opening the content.

--

Michael Lavender
Senior Environmental Health Officer, Adur & Worthing Councils
Phone: 01273 263343
Email: michael.lavender@adur-worthing.gov.uk
Website: Environmental Health
Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA

