

From: **Jeremy Sergeant** <jeremy.sergeant@adur-worthing.gov.uk>
Date: Thu, 12 Mar 2026 at 07:28
Subject: Re: AWDM/0078/26 and AWDM/0079/26 14 Ambrose Place
To: Louise Prew <louise.prew@adur-worthing.gov.uk>

Thank you for your email, from looking at the plans consideration has been given to existing trees and their RPAs by use of load bearing flexible porous subsurfaces in the form of Cellweb or similar. This should ensure that any path or hard standings does not affect the TPO trees.

Many thanks

Jeremy Sergeant

Senior Tree and Landscape Officer, Planning & Development
01273263477
Adur & Worthing Councils
Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA
<http://www.adur-worthing.gov.uk/>