

Comments for Planning Application AWDM/0448/26

Reps and Consults



planning@adur-worth

12:34 (33 minutes ago)

to me

Comments summary

Dear Sir/Madam,

Planning Application comments have been made. A summary of the comments is provided below.

Comments were submitted at 28/04/2026 12:34 PM from Planning Consents.

Application Summary

Address: Recreation Ground Old Barn Way Southwick West Sussex

Proposal: Application to Vary Conditions 1 (Approved Plans), 22 (levels) and 26 (surface water drainage) of previously approved AWDM/1217/23. Amendments: Repositioning of pitch; reduction in clubhouse size and alterations including relocation of main entrance; formation levels change and two new access ramps; amended surface water drainage strategy incorporating new soakaway design based on perimeter-only infiltration.
ORIGINAL DESCRIPTION: Redevelopment of the Former Southwick Football Club, comprising the replacement of existing turf pitch with 3G pitch and replacement floodlights, demolition of existing clubhouse and erection of replacement Sports Hub Building, erection of spectator stand along with other ancillary infrastructure.

Case Officer: Peter Barnett

[Click for further information](#)

Customer Details

Name: Planning Consents

Email: planningconsents@ukpowernetworks.co.uk

Address: UK Power networks Barton Road Bury st Edmunds

Comments Details

Commenter Type: Neighbour

Stance: Customer made comments neither objecting to or supporting the Planning Application

Reasons for comment:

Comments: Please note there are HV underground cables on the site running within close proximity to the proposed development. Prior to commencement of work accurate records should be obtained from our Plan Provision Department at UK Power Networks, Fore Hamlet, Ipswich, IP3 8AA.

All works should be undertaken with due regard to Health & Safety Guidance notes HS(G)47 (Avoiding Danger from Underground services). This document is available from local HSE office.

Should any diversion works be necessary as a result of the development then enquiries should be made to our Customer Connections department. The address is UK Power Networks, Metropolitan house, Darkes Lane, Potters Bar, Herts, EN6 1AG.

You can also find support and application forms on our website [Moving electricity supplies or equipment](#) | UK Power Networks
