From: Richard Small
Sent: 08 November 2018 14:54
To: Hannah Barker
Subject: Re: Manor House 14 Southwick Street Southwick AWDM/1337/18

Hi Hannah,

Its good news that no further ventilation is required. The other information is also fine and needs to form part of the application.

Richard

On Thu, 8 Nov 2018 at 11:15, Hannah Barker <hannah.barker@adur-worthing.gov.uk> wrote:

> Hi Richard I asked for your comments on this one a while ago. They have got back to me with the information requested.
> Please could I have your comments.
> Thanks Hannah
>
> ---------- Forwarded message ----------
> From: **RR Architects** <richard@rr-architects.co.uk>
> Date: Thursday, 8 November 2018
> Subject: Manor House 14 Southwick Street Southwick AWDM/1337/18
> To: Hannah Barker <hannah.barker@adur-worthing.gov.uk>
>
> Dear Hannah
>
> Further to our exchange of emails a few weeks ago the log burner installer has reported back after his site visit with the following comments:
>
> - No external ventilation system will be required for the size/capacity of the wood burners to be installed
> - The flue liners will be a 316 grade stainless steel flexible liner 150mm diameter
> - The bird guard rain caps will be as illustration below



I am hopeful that the listed building application can now got forward for determination.

Kind regards

Richard

Richard Robinson RIBA

RR Architects

3 Pacific Court,Riverside,

Shoreham by Sea, BN43 5RW

E-MAIL richard@rr-architects.co.uk

WEB www.rr-architects.co.uk

TEL 01273 452 634

MOB 07860 632 542

From: Hannah Barker [mailto:hannah.barker@adur-worthing.gov.uk]
Sent: 16 October 2018 12:14
To: RR Architects <richard@rr-architects.co.uk>
Subject: Re: Manor House 14 Southwick Street Southwick AWDM/1337/18

Thank you for the information. Yes I am happy to wait until after the survey to allow all matters to be clarified to avoid the need for a conditional approval.

I look forward to hearing from you after the survey.


Thank you

Hannah

Hannah Barker
Senior Planning Officer, Adur & Worthing Councils
Phone: 01903 221475
Email: hannah.barker@adur-worthing.gov.uk
Website: http://www.adur-worthing.gov.uk
Portland House
Richmond Road
Worthing
West Sussex
BN11 1HH

--

Hannah Barker
Senior Planning Officer, Adur & Worthing Councils
Phone: 01903 221475
Email: hannah.barker@adur-worthing.gov.uk
Website: http://www.adur-worthing.gov.uk
Portland House
Richmond Road
Worthing
West Sussex
BN11 1HH



--

Richard Small
Email: richard.small@adur-worthing.gov.uk
Website: www.adur-worthing.gov.uk
Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA

