From: planning@adur-worthing.gov.uk <planning@adur-worthing.gov.uk>
Sent: 10 July 2024 13:59:04 UTC+01:00
To: "planning@adur-worthing.gov.uk" <planning@adur-worthing.gov.uk>
Subject: Consultee Comments for Planning Application AWDM/0885/24

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 10/07/2024 1:59 PM from Mr Michael Lavender (michael.lavender@adur-worthing.gov.uk) on behalf of Environmental Health Public Health.

Application Summary

Reference:	AWDM/0885/24
Address:	Applewood Mill Lane Worthing West Sussex BN13 3DE
Proposal:	Installation of a domestic Air Source Heat Pump (12kW) to rear of dwelling
Case Officer:	Jason Albon

Click for further information

Comments Details

Comments:	The applicants calculations show the siting of the ASHP meets the MCS 020 noise assessment criteria for permitted development and therefore there are no EH objections to this application.

Kind regards