From: Richard Small <richard.small@adur-worthing.gov.uk> on behalf of Richard Small
Sent: 11 August 2020 11:17
To: Hannah Barker
Subject: Re: Hunter's Moon, BN43 5NJ AWDM/0676/19

Hi Hannah,

The mortar looks fine, but I am concerned about the width of the mortar between the flints. As these are being made to order locally, it should be possible to mount the flints closer together. It is important to emphasise that these blocks are being used due to their distance from the original Listed cottage, and that we would not normally support there use in relation to a Listed Building.

Kind regards
Richard

On Tue, 11 Aug 2020 at 09:51, Hannah Barker <hannah.barker@adur-worthing.gov.uk> wrote:

> Hi Richard,
> They are chasing this one....any news?
> Hannah
>
> ---------- Forwarded message ----------
> From: <randb@huntersmoon.net>
> Date: Tuesday, 11 August 2020
> Subject: Hunter's Moon, BN43 5NJ AWDM/0676/19
> To: Hannah Barker <hannah.barker@adur-worthing.gov.uk>
>
> Hi Hannah
>
> Just following up last week's enquiry: any response from Richard?
>
> Thanks
>
> Brian
>
> **From:** Ronny Flynn and Brian Sayer <randb@huntersmoon.net>
> **Sent:** 04 August 2020 09:53
> **To:** 'Hannah Barker' <hannah.barker@adur-worthing.gov.uk>
> **Cc:** 'PERRY CRAGG' <perryjcragg@btopenworld.com>
> **Subject:** Re: Hunter's Moon, BN43 5NJ AWDM/0676/19

Good morning Hannah

Has Richard given any feedback on our sample flint panel? The groundwork are nearing completion and wall construction should start next week.

Below are more pictures of the 'maturing' pointing, including a close up detail. We're very happy with how ii has come out!

Thanks

Brian





From: <randb@huntersmoon.net>
Sent: Tuesday, 28 July 2020, 18:29
To: 'Richard Small'; 'Hannah Barker'
Cc: 'PERRY CRAGG'
Subject: Hunter's Moon, BN43 5NJ AWDM/0676/19

Dear Richard

Hannah asked us to send you photos of the sample panel for the flint wall to our new extension.

This sample is approx. 450 x1200; obviously it's freshly made with lime-putty mortar which will dry much lighter and still needs to be rubbed off. We're working with South Downs Flint in Henfield who are experienced in meeting conservation requirements and are making the blocks to our specification, so if you need any adjustment it can easily be accommodated. Our principal contractor is Perry Cragg from Burgess Hill, who is copied into this email.


I've included elevations and a plan below that show the location of the new wall (highlighted in yellow). The adjacent extension which stands between the cottage and the new extension dates from the mid-1970s.


Best wishes

Brian

--

Hannah Barker
Senior Planning Officer, Adur & Worthing Councils
Phone: 01903 221475
Email: hannah.barker@adur-worthing.gov.uk
Website: http://www.adur-worthing.gov.uk
Portland House
Richmond Road
Worthing
West Sussex
BN11 1HH





--

Richard Small
Email: richard.small@adur-worthing.gov.uk
Website: www.adur-worthing.gov.uk
Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA

