From: **Michael Lavender** <michael.lavender@adur-worthing.gov.uk>
Date: Fri, 19 Sept 2025 at 12:57
Subject: AWDM/1100/25: Development Site 12 -18 Old Shoreham Road
To: Gary Peck <gary.peck@adur-worthing.gov.uk>

Hi Gary,

No objections with the noise condition being signed off.

The acoustician provides two options, continuous mechanical ventilation with trickle vents in the windows. This option requires enhanced glazing which is specified. The second option was MVHR which would do away with the need for trickle vents and would mean standard double glazing would be sufficient.Please can we get confirmation as to what option they choose?

Regards

Michael Lavender MCIEH AMIOA
Senior Environmental Health Officer
01273 263343
Environmental Health
Adur & Worthing Councils
Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA

For details on how we handle your data, please see our Privacy Notice.

https://www.adur-worthing.gov.uk/environmental-health/privacy-notice/