From: Anastasia Toleva <Anastasia.Toleva@westsussex.gov.uk> on behalf of Anastasia Toleva
Sent: 11 December 2020 14:41
To: Eve Hearsey
Subject: RE: AWDM/1397/20 - 48 Manor Road
Attachments: Response_AWDM-1397-20.pdf

Hi Eve,

Splays need amending plus the relocation of the tactile paving, please see my latest comments attached.

Kind Regards,

Anastasia Toleva | Technician | Information Management Team | Planning Services
West Sussex County Council
Location: Ground Floor Northleigh, County Hall, Chichester PO19 1QT
Internal: 24958| External: 0330 222 4958| Email: Anastasia.Toleva@westsussex.gov.uk

From: Eve Hearsey [mailto:eve.hearsey@adur-worthing.gov.uk]
Sent: 04 December 2020 09:41
To: Anastasia Toleva
Subject: AWDM/1397/20 - 48 Manor Road

Hi Anastasia

I attach the 2no. plans as discussed, please advise me if either one is what you were looking for.
Thanks very much
Eve

Eve Hearsey
Planning Officer, Adur & Worthing Councils
Phone: 01903 221233
Email: eve.hearsey@adur-worthing.gov.uk
Website: www.adur-worthing.gov.uk
Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please send it back to us, and immediately and permanently delete it. Do not use, copy or disclose the information contained in this message or in any attachment. Whilst every care has been taken to check this e-mail for viruses, it is your responsibility to carry out checks upon receipt.

LEGAL DISCLAIMER

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.

WEST SUSSEX COUNTY COUNCIL CONSULTATION

TO:	Adur & Worthing Councils FAO:Eve Hearsey
FROM:	WSCC - Highways Authority
DATE:	11 December 2020
LOCATION:	48 Manor Road Lancing BN15 0HG
SUBJECT:	AWDM/1397/20 Formation of vehicular access. New plans received.
DATE OF SITE VISIT:	n/a
RECOMMENDATION:	More Information
S106 CONTRIBUTION TOTAL:	n/a

This application has been dealt with in accordance with the Development Control Scheme protocol for small scale proposals which include up to 5 residential units or extensions to single units accessed from roads that do not form part of the Strategic Road Network (SRN). As such the comments provided by Local Development should be considered to be advice only, with respect to this planning application.

This proposal has been considered by means of a desktop study, using the information and plans submitted with this application, in conjunction with other available WSCC map information. A site visit can be arranged on request.

I refer to your consultation in respect of the above planning application and would provide the following comments.

The LHA has been re-consulted on this proposal following submission of revised plans demonstrating visibility splays at the proposed access.

The revised plans demonstrate visibility splays, however some of the drawings show splays drawn into the neighbouring properties and these cannot be taken into consideration as splays cannot be maintained in perpetuity if they fall within third party ownership.

Location plan scaled 1:1250 version (3) demonstrates visibility splays at the proposed access using a 2 'X' distance. A 2m 'X' distance in this location would be acceptable.

Splays to the west side has been drawn 3m into the carriageway. It should be drawn to the nearside carriageway edge or up to 1m into the carriageway to represent the edge of a vehicles track. This rule applies to both sides of the 'Y' distance. Therefore, the applicant would be requested to amend this detail to accord with the above guidance. The splays should be contained wholly within land under control of the applicant or that considered highway.

I note the presence of tactile paving crossing at the site frontage and the opposing side. Would this be lost or relocated (both sides) to another location, if so, where?

Please raise the above with the applicant and re-consult.

Anastasia Toleva
West Sussex County Council – Planning Services