Peter Barnett
Adur & Worthing Councils
Portland House,
Richmond Road,
Worthing,
BN11 1LF

19 December 2023

Dear Peter,

RE: **AWDM/1514/23 – Sompting Stables, West Street, Sompting, West Sussex**.

Thank you for your consultation on the above site. We have reviewed the application as the drainage consultant acting on behalf of the Council and wish to make the following comments.

The applicant is applying for the retention of four caravans and associated service block with introduction of evergreen hedges to front and side of site and dividing post and rail fencing.

Following a review of the submitted information, we have noted that the site has a high surface water flood risk. Therefore, **we would recommend the objection of the application** until a Flood Risk Assessment has been completed that assesses this risk.

Yours sincerely,

Louise Tedridge
Sustainable Water Management Officer

Matrix House
Basing View
Basingstoke, Hampshire
RG21 4FF
Tel: +44 1256 318 800
wsp.com

WSP UK Limited | Registered address: WSP House, 70 Chancery Lane, London WC2A 1AF
Registered in England and Wales No. 01383511