Southern Water

ADUR & WORTHING
31 JUL 2015
PLANNING SERVICES

Planning Services
Adur and Worthing Councils
Portland House
Richmond Road
Worthing
West Sussex
BN11 1LF

Developer Services
Southern Water
Southern House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119
Email: developerservices@southernwater.co.uk

Your Ref
AWDM/0601/15
Our Ref
PLAN-010467
Date
27/07/2015

Dear Sir

Proposal: Application for a Minor Material Amendment to planning permission AWDM/0501/12 to increase height of retaining wall to infilled slipway at Surry Hard by 0.3m.
Site: Former 79-81 Brighton Road, Shoreham-By-Sea, West Sussex, BN43 6RE.
AWDM/0601/15

Thank you for your letter of 10/07/2015

Please note there is 450mm surface water (brick) sewer within the site.

-No new foundations or construction works should be located within 3 metres either side of the centreline of the existing public surface water sewer.
-All other existing infrastructure should be protected during the course of construction works.

Yours sincerely

Developer Services

SOUTHERN WATER



The positions of pipes shown on this plan are believed to be correct, but Southern Water Services Ltd accept no responsibility in the event of inaccuracy. The actual positions should be determined on site.

Based upon Ordnance Survey Digital Data with the permission of the controller of H.M.S.O. Crown Copyright Reserved Licence No. WU 298530

Southern Water

O.S. REF: TQ2105SE	Scale: 1:250	Printed By: banuh	Date: 28-1-2013
Screen Print		Southern Water MapGuide Browser	
WARNING: BAC pipes are constructed of Bonded Asbestos Cement		Requested By:	
WARNING: Unknown (UNK) materials may include Bonded Asbestos Cement			

N