Free Wharf, Shoreham, West Sussex Surface Water (SUDs) (AWDM/0255/19)

1 message

Stephen Cantwell <stephen.cantwell@adur-worthing.gov.uk> 4 September 2019 at 12:01
To: Stephen Cantwell <stephen.cantwell@adur-worthing.gov.uk>

From: **DaSilva, Luis** <Luis.DaSilva@southernwater.co.uk>
Date: Wed, 4 Sep 2019 at 11:47
Subject: RE: Free Wharf, Shoreham, West Sussex Surface Water (SUDs) (AWDM/0255/19)
To: Stephen Cantwell <stephen.cantwell@adur-worthing.gov.uk>, Mayall, Charlotte <Charlotte.Mayall@southernwater.co.uk>

Good morning Stephen,

Thank you for your email.

Surface water- condition 8

We only comment on surface water disposal (i.e. SUDs) if the drainage layout shows any SUDs features within 5 metres of Southern Water apparatus which not the case here. Southern Water has no objection in regards to surface water disposal to watercourse.

Foul water- Condition 9

I have noticed that due to lack of capacity this site has been referred to our growth scheme and therefore off – site infrastructure works is to be provide as part of Southern Water capital scheme.

Kind regards

Luis Silva

Planning Co-ordinator

For Sussex

T. 0330 303 0119

southernwater.co.uk sw-email-logo