Consultee Comments for Planning Application AWDM/0556/21

1 message

planning@adur-worthing.gov.uk <planning@adur-worthing.gov.uk> 14 April 2021 at 15:09
To: planning@adur-worthing.gov.uk

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 14/04/2021 3:09 PM from Miss Gabrielle Peak (gabrielle.peak@adur-worthing.gov.uk) on behalf of Environmental Health Public Health.

Application Summary

Reference:	AWDM/0556/21
Address:	55 Hammy Way Shoreham-By-Sea West Sussex BN43 6GH
Proposal:	Proposed rear and side single-storey extension to north and east elevations for use as attached annexe.
Case Officer:	Marie O'Keeffe

Click for further information

Comments Details

Comments:	In regards to application AWDM/0556/21 - please see recommended condition. Works of construction or demolition, including the use of plant and machinery, necessary for implementation of this consent shall be limited to the following times. Monday - Friday 08:00 - 18:00 Hours Saturday 09:00 - 13:00 Hours Sundays and Bank Holidays no work permitted Any temporary exception to these working hours shall be agreed in writing by the Local Planning Authority at least five days in advance of works commencing. The contractor shall notify the local residents in writing at least three days before any such works.

Kind regards