Paul Trussler
44 Firle Road
North Lancing
West Sussex
BN15 0NZ

Tel: 01903 767147

For the attention of Mr C Hone
Planning Services
Adur District Council
Civic Centre
Ham Road
Shoreham-by-Sea
West Sussex
BN43 6PR

13 November 2009
Your Ref: ADC/0074/09

Dear Mr Hone

21 Howard Road, Sompting, Lancing, West Sussex. BN15 0LW
Proposed roof extensions

Further to our recent telephone conversation relating to the window to the lounge on the front elevation in respect of the above.

As discussed this window was approved as a 3 pane window to match the window in the first floor roof dormer. It has been found that whether the new window to the lounge is constructed with pvc'u or timber the window manufacturer's will not guarantee the window or the sealed unit double glazing. This is due to the effect that the weight of the opening casement windows (1500mm deep) will have on the hinges and the window frame itself.


Therefore, we would like to change the style of this window still as 3 panes but with top hung vents over the side casements only. I have attached a revised front elevation showing this proposal for your consideration.

I look forward to receiving your comments in due course.

Yours sincerely

Paul Trussler


encl.




Proposed Front Elevation.


Proposed

Elevations 1:100



Proposed Side Elevation.





Existing Side Elevation.

Roof alterations : *for Mr T Jenkins & Ms M Maddocks*
21 HOWARD ROAD, SOMPTING, WEST SUSSEX. BN15 0LW