Peter Barnett
Adur & Worthing Councils
Portland House,
Richmond Road,
Worthing,
BN11 1LF

2 October 2024

Dear Peter,

RE: ADWM/1001/24- St Peter's House, 107a Gardner Road, Southwick

Thank you for your consultation on the above site. We have reviewed the application as the drainage consultant acting on behalf of the Council and wish to make the following comments.

Following a review of the submitted information and the clarification received in regards to the distance between the building and the boundaries being less than 5m which would impact infiltration from occurring in this area, the details are in accordance with the planning condition.

Yours sincerely

Katherine Waters

Sustainable Water Management Technical Specialist

Matrix House
Basing View
Basingstoke, Hampshire
RG21 4FF
Tel: +44 1256 318 800
wsp.com

WSP UK Limited | Registered address: WSP House, 70 Chancery Lane, London WC2A 1AF
Registered in England and Wales No. 01383511