Mike Jeffrey
Buckingham Group Contracting Ltd
Blackpit Farm
Silverstone Road
Stowe
Buckingham MK18 5LJ

23 May 2014 Our ref 271BHAg140522-1216l.docx

Dear Mike

Brighton and Hove Training Academy
BREEAM Interim Design Stage Assessment

We are writing to confirm that we have completed the BREEAM interim design stage assessment for the BHAFC Training Academy. We will be recommending to BRE that the awarded score is 56.7%. This score is above the threshold for the 'Very Good' rating (55%), however because the mandatory credit under LE03 has not been achieved, therefore a 'Good' rating can be achieved.

We will submit to BRE for certification and will forward the certificate once received.

We look forward to completing the final post construction assessment with you.

Yours sincerely

[redacted]

Natasha Fox
Sustainability Consultant
Natasha.fox@methodllp.com
Direct Dial: 01793 836607

ADUR & WORTHING
PLANNING SERVICES

PLAN	AWDM/ 0896/14
DATE VALID	15 JUL 2014