From: **Haydn Jones** <haydn@savillejones-architects.com>
Date: Thu, 14 Nov 2024 at 11:59
Subject: RE: FW: AWDM/1108/24 14 Ambrose Place
To: Louise Prew <louise.prew@adur-worthing.gov.uk>
Cc: Giulio Oliviero <giulio@savillejones-architects.com>

Morning Louise

Good to meet you yesterday and please find attached a photograph of the masonry sample wall.

To confirm the sample was acceptable in terms of brickwork, flint joints and mortar colour, it was however agreed to add a gravel to the flint mortar joint, mix to match existing walls. Note the contractor has confirmed that a traditional - 1.1.6 cement: lime: sand mortar mix was used.

It was also agreed that early on in construction of the external wall, we will inspect and forward a photograph to the planning department for record purposes.

As discussed yesterday the contractors are due to commence works in the next 2 weeks and it would be helpful if the condition can be discharged beforehand.

Regards
Haydn