From: planning@adur-worthing.gov.uk
Sent: 26 May 2022 12:53
To: planning@adur-worthing.gov.uk
Subject: Consultee Comments for Planning Application AWDM/0723/22

Flag Status: Flagged

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 26/05/2022 12:52 PM from Mrs Hannah Powell (hannah.powell@adur-worthing.gov.uk) on behalf of Environmental Health Public Health.

Application Summary

Reference:	AWDM/0723/22
Address:	Unit 5 52 Dolphin Road Shoreham-by-sea West Sussex BN43 6PB
Proposal:	Approval of Details Reserved by Condition 5 (Acoustic Attenuation Measures) of Application No AWDM/0126/21
Case Officer:	Peter Barnett

Click for further information

Comments Details

Comments:	With reference to the above application relating to the requirement of condition 5 of Application No AWDM/0126/21. The BS4142:2014-A1:2019 Noise Survey & Assessment (Date: 03/03/2022 Project: J3324) submitted with this application demonstrates that the cumulative rating level of the proposed plant are significantly below the existing L90 Background Sound Level and are therefore unlikely to cause an adverse impact at the nearest noise sensitive receptors. This assessment complies with the requirements of condition 5 and is considered to be acceptable. All plant shall be maintained in accordance with manufacturers guidance.

Kind regards