Expiry Date - 07/08/2023

Development Control – Delegated Officer Report

Application Number: AWDM/0818/23 Recommendation – APPROVE

Site: 14 Dianthus Grove Northbrook Worthing West Sussex

Proposal: Application for Certificate of Lawfulness for proposed rear extension

Site visit: N

Proposal, Site and Surroundings

The property is a two storey detached dwelling. The site is on the south side of Diathus Grove situated on a corner plot. The property is a newly built property with no restrictive conditions regarding rear single storey extensions. (AWDM/1882/16 and AWDM/1714/19 refer). The property is predominately built with flint covered walls with brick detailing. The property is not within a Conservation Area and is not Listed.

Planning Assessment

Principle

The proposal will be viewed against the criteria of permitted development, as laid out within The Town and Country Planning (General Permitted Development) (England) Order 2015

Consideration

Schedule 2, Part 1, Development within the curtilage of a dwellinghouse Permitted Development

<u>Class A – Enlargement, improvement or other alteration of a dwellinghouse</u>

A.1 Development is not permitted by Class A if-

a) permission to use the dwellinghouse as a dwellinghouse has been granted only by virtue of Class M, N, P, PA or Q of Part 3 of the Schedule (changes of use);

Analysis: . The dwellinghouse has not been created through change of use by virtue of Part 3. .

b) as a result of the works, the total area of ground covered by buildings within the curtilage of the dwellinghouse (other than the original

dwellinghouse) would exceed 50% of the total area of the curtilage (excluding the ground area of the original dwellinghouse);

Analysis: The ground cover by extension(s) will not exceed 50% of the total area of curtilage.

c) the height of the part of the dwellinghouse enlarged, improved or altered would exceed the height of the highest part of the roof of the existing dwellinghouse;

Analysis: The height of the proposed extension does not exceed the height of the highest part of the roof of the existing dwellighouse.

d) the height of the eaves of the part of the dwellinghouse enlarged, improved or altered would exceed the height of the eaves of the existing dwellinghouse;

Analysis: The height of the eaves of the proposed extension does not exceed the height of the eaves of the existing dwellinghouse.

e) the enlarged part of the dwellinghouse would extend beyond a wall which:
i) forms the principal elevation of the original dwellinghouse; or
ii) fronts a highway and forms a side elevation of the original dwellinghouse;

Analysis: The proposed extension does not extend beyond a wall which form the principal elevation of the original dwelling house and does not front a highway and forms a side elevation of the original dwellinghosue.

f) subject to paragraph g) the enlarged part of the dwellinghouse would have a single storey and-
i) extend beyond the rear wall of the original dwellinghouse by more than 4m in the case of a detached dwellinghouse, or 3m in the case of any other dwellinghouse, or
ii) exceed 4m in height;

Analysis: The proposed extension is single storey and does not extend beyond the original rear wall of the dwellinghouse by more than 4m and does not exceed 4m in height.

g) for a dwellinghouse not on article 2(3) land nor on a site of special scientific interest, the enlarged part of the dwellinghouse would have a single storey and-
i) extend beyond the rear wall of the original dwellinghouse by more than 8 m in the case of a detached dwellinghouse, or 6m in the case of any other dwellinghouse, or
ii) exceed 4m in height;

Analysis: The site is not on article 2(3) land and he proposed extension is single storey and does not extend beyond the original rear wall of the dwellinghouse by more than 4m and does not exceed 4m in height.

ah) the enlarged part of the dwellinghouse would have more than a single storey and-
i) extend beyond the rear wall of the original dwellinghouse by more than 3m, or
ii) be within 7 m of any boundary of the curtilage of the dwellinghouse being enlarged which is opposite the rear wall of that dwellinghouse;

Analysis: . The proposed extension will not be more than a single storey, therefore i) and ii) do not need to be considered.

i) the enlarged part of the dwellinghouse would be within 2m of the boundary of the curtilage of the dwellinghouse, and the height of the eaves of the enlarged part would exceed 3m;

Analysis: The proposed single storey extension is within 2m of the boundary and the eaves of the proposed extension do not exceed 3m in height.

j) the enlarged part of the dwellinghouse would extend beyond a wall forming a side elevation of the original dwellinghouse, and would-
i) exceed 4m in height;
ii) have more than a single storey; or
iii) have a width greater than half the width of the original dwellinghouse; or
(ja) any total enlargement (being the enlarged part together with any existing enlargement of the original dwellinghouse to which it will be joined) exceeds or would exceed the limits set out in sub-paragraphs (e) to (j).

Analysis: The proposed single storey extension does not extend beyond a wall which forms a side elevation of the dwellinghouse and therefore i)-iii) not not apply. There is no other enlargement for the proposed extension to join to.

k) it would consist of or include-
i) the construction or provision of a verandah, balcony or raised platform,
ii) the installation, alteration or replacement of a microwave antenna,
iii) the installation, alteration or replacement of a chimney, flue or soil and vent pipe, or
iv) an alteration to any part of the roof of the dwellinghouse.

Analysis: . None of the above apply.

(l) the dwellinghouse is built under Part 20 of this Schedule (construction of new dwellinghouses).

Analysis: The dwellinghouse has not been created by virtue of Part 20.

A.2 In the case of a dwellinghouse on article 2(3) land:-

a) it would consist of cladding of any part of the exterior of the dwelling house with stone, artificial stone, pebble dash, render, plastic or tiles.

b) the enlarged part of the dwellinghouse would extend beyond a wall forming a side elevation of the original dwellinghouse;
c) the enlarged part of the dwellinghouse would have more than a single storey and extend beyond the rear wall of the original dwelling house.
d) any total enlargement (being the enlarged part together with any existing enlargement of the original dwellinghouse to which it will be joined) exceeds or would exceed the limits set out in sub-paragraphs (b) and (c).

Analysis: .The dwelling is not on article 2(3) land.

A.3 Development is permitted subject to:-

a) materials must be of a similar appearance to those used in the construction of the exterior of the existing dwelling;
b) any upper-floor windows located in a wall or roof slope forming a side elevation must be:-
    i) obscured-glazed, and
    ii) non-opening unless the parts of the window which can be opened are more than 1.7m above the floor of the room in which the window is installed.
c) Where the enlarged part of the dwelling house has more than one storey or forms an upper storey on an existing enlargement of the original dwelling house the roof pitch of the enlarged part must so far as practicable be the same as the roof pitch of the original dwellinghouse.

Analysis: The proposed extension is to be built in flintwork (blocks) with brick dressings to the side elevations (to match the pointing style, mortar texture and colour to match the existing dwelling), and face brickwork to the rear elevation. Owing to the size of the proposed bi-fold door and window openings it is recognised use of flintwork on the rear would have limited visual impact such as to be impractical when taking into consideration the brick quoining around the edges of the openings and corners of the extension that would be necessary to match the brick dressings on the existing dwelling. In the circumstances it is accepted that the criteria A.3 is adequately met in this instance. The proposed extension is single storey and therefore b – c do not apply.

Recommendation

Issue a Certificate of Lawfulness for Proposed Development, the submission of a planning application for the works will not be required.

Reasons for Recommendation

The proposal constitutes 'development' as defined by Section 55 of the Town and Country Planning Act 1990, but is permitted by Class A of Part 1 Schedule 2 of Town and Country Planning (General Permitted Development) (England) Order 2015.

Expiry Date - 07/08/2023

Case Officer: Elaine Rousseau Date: 10/08/2023

Authorised by: Jo Morin Date: 10.08.2023