SFWR
Steel Frame Window Refurbishment

Unit Z2, Mackleys Industrial Estate,
Henfield Road, Small Dole,
West Sussex.BN5 9XR
Office: 01273 916597
Factory: 01273 493493

Fairlawn Construction

Site : grand Vic hotel Worthing

Scope of works to fabricate and fit decorative railings to raised area.

Material used b.

10 mm base plates4 holes in plates

30 x 8 bottom bar

12mm solid round bar

40 x 10 top rail

Posts 40 x 40 x 3mm square section for posts

Finial to top of rail

See attached material certificates for items used

All of the above fully welded together to form railings decking was cut away to allow base plates to be drilled and chemfix to slab with 12mm studs

Regards Graham Ashe



150 x 10 BASE PLATES

LAMINÉS MARCHANDS EUROPÉENS A04
AFV BELTRAME GROUP

Z04 CE 0398
complete CE Marking on next page

A06 **BARCLAY & MATHIESON LTD**
SHIELDHALL WORKS HARDGATE ROAD
GB G514T GLASGOW -

A03
INSPECTION DOCUMENT N.: **1173706**
OFFICIAL REGULATION: **EN 10025-2/2019**

A02
INSPECTION CERTIFICATE **3.1 - EN10204**
ENCLOSE CERTIFICATION CE

C70 **Steel from electric arc furnace**

A10 **Environmental product declaration : ICQM - 20112EPD**

AGENT ORDER N. **178/2233208**
CUSTOMER CODE **8275**
A07 CUSTOMER ORDER N. **212453**
CONSIGNEE **BARCLAY & MATHIESON LTD**
B02 B04 GRADE **S275JR+AR**

LOADING NUMBER: 479246 **LOADING DATE: 09/08/2023** A08 **INTERNAL ORDER: E 957251**

IT.	B07 CAST	B01 SECTION	B09 - B10 - B11 DIMENSIONS mm	CE	LENGTH mt	C71->C92 C	Si	Mn	P	S	Cu	Cr	Ni	V	Mo	Ti	Nb	N	Ceq	Al
4	LM 113132	FLAT	150X10	0398	6,00	0,07	0,17	0,57	0,018	0,035	0,34	0,08	0,15	0,004	0,03	0,0010	0,0010	0,0062	0,220	0,0022

IT.	B07 CAST	A01 ORIGIN	PRODUCT REGULATION	C00 TEST NUM	B08 Bdls n.	B13 WEIGHT Kg	TENSILE TEST C11 ReH/MPa	C12 Rm/MPa	C13 A5%	Z%	IMPACT TEST C42 C42 C42 C43 Kv 300/10 J Mean	C03 °C	C41 w/mm	RATIO REDUC.	BEND <	TEST D	GRAIN	HARDNESS	INSPECTION SUP.INSIDE	ANTI MIX.
4	LM 113132	TRITH	EN 10058	2121452	1	2.311	289	413	34,3											

INSPECTOR | FACTORY: TRITH ST LEGER | Z02 DATE: 09/08/23 | A05 QUALITY CONTROL DEPT: Florian Rezende | Document validated by electronic sign | Z02 QUALITY ASSURANCE DEPT: Christophe Filareto

Cast/Heat No: LM113132 Mill Ref: Certificate Ref: 1173706

This is a true copy of the test certificate

Laminés Marchands Européens S.A.S. - 2, rue Emile Zola - 59125 Trith Saint Léger (France)
Tél. +33 (0)3 27 14 20 20 - Fax +33 (0)3 27 14 20 10 - S.A.S. au Capital de 32.300.345 € RCS Valenciennes B 568 801 013
N° SIRET 568 801 013 00018 - N° d'identification à la TVA FR 03 568 801 013 - contact@lme.fr - www.gruppobeltrame.com

Z01 We hereby certify that above mentioned materials have been delivered in accordance with the terms of order.
D01 Surface control and dimensional check = satisfactory
C42 and C43 recalculated Impact test results respect to 10x10 standard section

INDUSTRIAL METAL SERVICES
Metalstock House, Vanguard Way,
Shoeburyness, Southend-on-Sea, Essex SS3 9RE
Registered No. SC030987 VAT No. GB723932239

MATERIAL CERTIFICATE
Customer: SFWR LTD
Customer Ref:
Sales Order no: 482941.03
Despatch No:
Product: 150 X 10 MILD STEEL FLAT
Size: 6.100 x 150.000
Quantity: 1
Delivery Date: 12/09/23

More than Steel
Tel: 01702 296955
Fax: 01702 296444
sales@industrialmetal.co.uk
www.industrialmetal.co.uk

40+8 TOP RAIL

INDUSTRIAL METAL SERVICES
Metalstock House, Vanguard Way.
Shoeburyness, Southend-on-Sea, Essex SS3 9RE
Registered No. SC030987 VAT No. GB723932239

MATERIAL CERTIFICATE

LAMINÉS MARCHANDS EUROPÉENS A04
AFV BELTRAME GROUP

Z04 CE 0398
complete CE Marking on next page

A06 BARCLAY & MATHIESON LTD
SHIELDHALL WORKS HARDGATE ROAD
GB G514T GLASGOW -

A03
INSPECTION DOCUMENT N.: 1173790
OFFICIAL REGULATION: EN 10025-2/2019

A02
INSPECTION CERTIFICATE 3.1 - EN10204
ENCLOSE CERTIFICATION CE

C70 Steel from electric arc furnace

A10 Environmental product declaration : ICQM - 20112EPD

AGENT ORDER N. 178/2233731
CUSTOMER CODE 8275
A07 CUSTOMER ORDER N. 212511
CONSIGNEE BARCLAY & MATHIESON LTD
B02 B04 GRADE S275JR+AR

LOADING NUMBER: 479336 LOADING DATE: 09/08/2023 A08 INTERNAL ORDER: E 957446

IT.	B07 CAST	B01 SECTION	B09 - B10 - B11 DIMENSIONS mm	CE	LENGTH mt	C71->C92 C	Si	Mn	P	S	Cu	Cr	Ni	V	Mo	Ti	Nb	N	Ceq	Al
1	LM 112800	ANGLE	100X100X10	0398	12,00	0,07	0,18	0,57	0,028	0,034	0,31	0,16	0,11	0,004	0,02	0,0012	0,0010	0,0066	0,230	0,0022
3	LM 111590	FLAT	40X8	0398	6,00	0,07	0,18	0,59	0,018	0,035	0,37	0,09	0,10	0,004	0,02	0,0014	0,0012	0,0063	0,221	0,0028
3	LM 111660	FLAT	40X8	0398	6,00	0,07	0,18	0,55	0,018	0,032	0,35	0,08	0,12	0,004	0,02	0,0013	0,0010	0,0065	0,213	0,0024
4	LM 113249	FLAT	50X8	0398	6,00	0,07	0,20	0,57	0,017	0,029	0,37	0,07	0,11	0,003	0,02	0,0015	0,0010	0,0072	0,217	0,0025
4	LM 113261	FLAT	50X8	0398	6,00	0,07	0,15	0,54	0,022	0,035	0,26	0,08	0,11	0,004	0,02	0,0012	0,0010	0,0077	0,206	0,0023
8	LM 111967	FLAT	200X10	0398	6,00	0,10	0,18	0,53	0,016	0,022	0,36	0,10	0,12	0,004	0,02	0,0014	0,0010	0,0094	0,243	0,0029

IT.	B07 CAST	A01 ORIGIN	PRODUCT REGULATION	C00 TEST NUM	B08 Bdls n.	B13 WEIGHT Kg	TENSILE TEST C11 ReH/MPa	C12 Rm/MPa	C13 A5%	Z%	IMPACT TEST C42 C42 C42 C43 Kv 300/10 J Mean	C03 °C	C41 w/mm	RATIO REDUC.	BEND TEST <	D	GRAIN	HARDNESS	INSPECTION SUP. INSIDE	ANTI MIX.
1	LM 112800	TRITH	EN 10056-1	2121559	1	2.220	290	414	34,1											
3	LM 111590	TRITH	EN 10058	2119149	3	7.212	291	420	34,2											
3	LM 111660	TRITH	EN 10058	2119173	1	2.474	290	415	34,2											
4	LM 113249	TRITH	EN 10058	2121604	1	2.364	287	417	34,4											
4	LM 113261	TRITH	EN 10058	2121618	1	2.374	291	411	34,5											
8	LM 111967	TRITH	EN 10058	2119536	2	4.671	306	419	32,2											

INSPECTOR
FACTORY: TRITH ST LEGER
Z02 DATE: 09/08/23
A05 QUALITY CONTROL DEPT: Florian Rezende
Document validated by electronic sign
Z02 QUALITY ASSURANCE DEPT: Christophe Filareto

Laminés Marchands Européens S.A.S. - 2, rue Emile Zola - 59125 Trith Saint Léger (France)
Tél. +33 (0)3 27 14 20 20 - Fax +33 (0)3 27 14 20 10 - S.A.S. au Capital de 32.300.345 € RCS Valenciennes B 568 801 013
N° SIRET 568 801 013 00018 - N° d'identification à la TVA FR 03 568 801 013 - contact@lme.fr - www.gruppobeltrame.com

Z01 We hereby certify that above mentioned materials have been delivered in accordance with the terms of order.
D01 Surface control and dimensional check = satisfactory
C42 and C43 recalculated Impact test results respect to 10x10 standard section

Customer: SFWR LTD
Customer Ref:
Sales Order no: 483926.04
Despatch No:
Product: 40 X 8 MILD STEEL FLAT
Size: 6.100
Quantity: 3
Delivery Date: 15/09/23

More than Steel
Tel: 01702 296955
Fax: 01702 296444
sales@industrialmetal.co.uk
www.industrialmetal.co.uk

Cast/Heat No: LM111660 Mill Ref: Certificate Ref: 1173790

This is a true copy of the test certificate

30x8 BOTTOM RAIL

12MM ROUND

LAMINÉS MARCHANDS EUROPÉENS

AFV BELTRAME GROUP

A04

Z04 CE 0398

complete CE Marking on next page

A03
INSPECTION DOCUMENT N.: 1173247
OFFICIAL REGULATION: EN 10025-2/2019

A02
INSPECTION CERTIFICATE 3.1 - EN10204
ENCLOSE CERTIFICATION CE

C70 Steel from electric arc furnace

A10 Environmental product declaration : ICQM - 20112EPD

A06 BARCLAY & MATHIESON LTD

SHIELDHALL WORKS HARDGATE ROAD

GB G514T GLASGOW -

AGENT ORDER N. 178/2232312
CUSTOMER CODE 8275
A07 CUSTOMER ORDER N. 212332
CONSIGNEE BARCLAY & MATHIESON LTD
B02 B04 GRADE S275JR+AR

LOADING NUMBER: 478826 LOADING DATE: 02/08/2023 A08 INTERNAL ORDER: E 956788

IT.	B07 CAST	B01 SECTION	B09-B10-B11 DIMENSIONS mm	CE	LENGTH mt	C71->C92 C	Si	Mn	P	S	Cu	Cr	Ni	V	Mo	Ti	Nb	N	Ceq	Al
2	LM 111352	ANGLE	40X40X4	0398	6,00	0,07	0,18	0,62	0,020	0,035	0,37	0,09	0,17	0,004	0,03	0,0010	0,0010	0,0063	0,237	0,0022
3	LM 113090	ANGLE	100X100X10	0398	6,00	0,07	0,20	0,65	0,014	0,028	0,33	0,06	0,14	0,003	0,02	0,0013	0,0010	0,0084	0,227	0,0024
4	LM 111614	FLAT	30X8	0398	6,00	0,08	0,18	0,59	0,019	0,035	0,34	0,09	0,11	0,004	0,02	0,0013	0,0010	0,0086	0,232	0,0026
5	LM 111098	FLAT	50X5	0398	6,00	0,07	0,18	0,56	0,026	0,034	0,37	0,09	0,15	0,004	0,03	0,0011	0,0010	0,0098	0,224	0,0025
7	LM 113304	ROUND	16	0398	6,00	0,07	0,15	0,63	0,020	0,030	0,26	0,07	0,10	0,004	0,02	0,0014	0,0010	0,0098	0,221	0,0026
8	LM 113342	ROUND	20	0398	6,00	0,08	0,22	0,70	0,019	0,034	0,36	0,07	0,11	0,004	0,02	0,0011	0,0010	0,0101	0,248	0,0021
10	LM 111957	FLAT	200X10	0398	6,00	0,09	0,21	0,58	0,017	0,034	0,33	0,09	0,11	0,004	0,02	0,0013	0,0010	0,0085	0,244	0,0025
12	LM 108878	UN. ANG.	65X50X5	0398	6,00	0,09	0,16	0,57	0,026	0,034	0,39	0,08	0,13	0,002	0,02	0,0006	0,0010	0,0116	0,238	0,0022

IT.	B07 CAST	A01 ORIGIN	PRODUCT REGULATION	C00 TEST NUM	B08 Bdls n.	B13 WEIGHT Kg	TENSILE TEST C11 ReH/MPa	C12 Rm/MPa	C13 A5%	Z%	IMPACT TEST C42 C42 C42 C43 Kv 300/10 J Mean	C03 °C	C41 w/mm	RATIO REDUC.	BEND TEST < D	GRAIN	HARDNESS	INSPECTION SUP.INSIDE	ANTI MIX.
2	LM 111352	TRITH	EN 10056-1	2120952	2	4.862	302	442	34,8										
3	LM 113090	TRITH	EN 10056-1	2121502	1	2.143	290	427	34,0										
4	LM 111614	TRITH	EN 10058	2119213	1	2.292	299	425	33,5										
5	LM 111098	TRITH	EN 10058	2117758	2	4.549	296	426	34,6										
7	LM 113304	TRITH	EN 10060	2121688	2	4.486	284	413	35,0										
8	LM 113342	TRITH	EN 10060	2121719	1	2.400	295	436	32,9										
10	LM 111957	TRITH	EN 10058	2119523	2	4.515	300	427	32,5										
12	LM 108878	TRITH	EN 10056-1	2114019	1	2.313	309	433	33,6										

INSPECTOR FACTORY Z02 DATE A05 QUALITY CONTROL DEPT Document validated by electronic sign Z02 QUALITY ASSURANCE DEPT

TRITH ST LEGER 02/08/23 Florian Rezende Christophe Filareto

Laminés Marchands Européens S.A.S. - 2, rue Emile Zola - 59125 Trith Saint Léger (France)
Tél. +33 (0)3 27 14 20 20 - Fax +33 (0)3 27 14 20 10 - S.A.S. au Capital de 32.300,345 € RCS Valenciennes B 568 801 013
N° SIRET 568 801 013 00018 - N° d'identification à la TVA FR 03 568 801 013 - contact@lme.fr - www.gruppobeltrame.com

Z01 We hereby certify that above mentioned materials have been delivered in accordance with the terms of order.
D01 Surface control and dimensional check = satisfactory
C42 and C43 recalculated Impact test results respect to 10x10 standard section

bsi ISO 9001 Quality Management Systems CERTIFIED

Cast/Heat No: LM 111614 Mill Ref: Certificate Ref: 1173247

This is a true copy of the test certificate

Page 1 of 2

UK CA

IMS
INDUSTRIAL METAL SERVICES
Metalstock House, Vanguard Way,
Shoeburyness, Southend-on-Sea, Essex SS3 9RE
Registered No. SC030987 VAT No. GB723932239

MATERIAL CERTIFICATE

Customer: SFWR LTD
Customer Ref:
Sales Order no: 483926.05
Despatch No:
Product: 30 X 8 MILD STEEL FLAT
Size: 6.100 x 30.000
Quantity: 3
Delivery Date: 15/09/23

More than Steel
Tel: 01702 296955
Fax: 01702 296444
sales@industrialmetal.co.uk
www.industrialmetal.co.uk

12mm ROUND
INFIL BARS

AFV BELTRAME GROUP A04

Z04 CE 0398

complete CE Marking on next page

A06 EPS STEEL UK LTD

EASTGATE 79 - MID GLAMORGAN

GB CF71 7AA COWBRIDGE

A03
INSPECTION DOCUMENT N.: 405660
OFFICIAL REGULATION: EN 10025-2/2019

A02
INSPECTION CERTIFICATE 3.1 - EN10204
ENCLOSE CERTIFICATION CE

C70 Steel from electric arc furnace

A10 Environmental product declaration : ICQM - 17029EPD

AGENT ORDER N. 178/2226874
CUSTOMER CODE 10112
A07 CUSTOMER ORDER N. AFV23-003
CONSIGNEE EPS STEEL UK LTD
B02 B04 GRADE S275JR+AR

LOADING NUMBER: 717139 LOADING DATE: 16/06/2023 A08 INTERNAL ORDER: E 879909

IT.	B07 CAST	B01 SECTION	B09-B10-B11 DIMENSIONS mm	CE	LENGTH mt	C71->C92 C	Si	Mn	P	S	Cu	Cr	Ni	V	Mo	N	Ceq			
1	BE 212801	UN. ANG.	40X25X4	0398	6,00	0,13	0,17	0,57	0,016	0,025	0,43	0,12	0,16	0,002	0,04	0,0117	0,30			
2	BE 217207	FLAT	80X12	0398	6,00	0,13	0,18	0,59	0,023	0,024	0,47	0,14	0,17	0,003	0,03	0,0114	0,31			
3	BE 203301	ROUND	50	0398	6,00	0,13	0,19	0,57	0,017	0,019	0,49	0,12	0,16	0,005	0,03	0,0096	0,30			
4	BE 216334	ROUND	6	0398	6,00	0,11	0,18	0,54	0,026	0,014	0,43	0,20	0,18	0,002	0,03	0,0113	0,29			
5	BE 209505	SQUARE	10	0398	6,00	0,11	0,21	0,54	0,019	0,022	0,43	0,12	0,14	0,002	0,03	0,0105	0,27			
6	BE 215724	FLAT	25X12	0398	6,00	0,12	0,18	0,61	0,020	0,008	0,39	0,14	0,20	0,002	0,04	0,0114	0,29			
7	BE 215510	FLAT	25X15	0398	6,00	0,12	0,16	0,60	0,017	0,019	0,40	0,17	0,21	0,003	0,04	0,0118	0,30			
8	BE 208914	UN. ANG.	60X30X5	0398	6,00	0,10	0,14	0,56	0,025	0,019	0,38	0,15	0,14	0,002	0,03	0,0097	0,27			

IT.	B07 CAST	A01 ORIGIN	PRODUCT REGULATION	C00 TEST NUM	B08 Bdls n.	B13 WEIGHT Kg	TENSILE TEST C11 ReH/MPa	C12 Rm/MPa	C13 A5%	Z%	IMPACT TEST C42 C42 C42 C43 KV 300/10 J Mean	C03 °C	C41 w/mm	RATIO REDUC.	BEND <	TEST D	GRAIN	HARDNESS	INSPECTION SUP.INSIDE	ANTI MIX.
1	BE 212801	SG.VALDARNO	EN 10056-1	4508014	3	5.781	337	466	31,1											
2	BE 217207	VICENZA	EN 10058	6053464	1	2.519	322	483	35,0											
3	BE 203301	S.DIDERO	EN 10060	3019209	1	2.417	321	442	30,3											
4	BE 216334	S.DIDERO	EN 10060	3020848	1	2.249	319	442	31,7											
5	BE 209505	S.DIDERO	EN 10059	3020712	1	2.483	308	433	31,6											
6	BE 215724	SG.VALDARNO	EN 10058	4508362	1	2.382	319	445	31,0											
7	BE 215510	SG.VALDARNO	EN 10058	4508359	1	2.316	322	443	30,8											
8	BE 208914	VICENZA	EN 10056-1	2098913	1	2.545	316	442	33,1											

Inspector Factory VICENZA Z02 Date 16/06/23 A05 Quality Control Dept Z02 Manufacturer's authorized inspection representative Silvia Ghini

AFV Acciaierie Beltrame S.p.A. - Sede Legale e Direzione Centrale: Viale della Scienza, 81 - 36100 Vicenza (Italy)
Ph +39 0444 967111 - Fax +39 0444 348577 Sales Dept. +39 0444 348591 - Purchasing Dept. +39 0444 348579
Codice Fiscale, Registro Imprese Vicenza e Partita IVA 13017310155 - R.E.A. Vicenza nr. 292852
Codice identificazione CEE IT 13017310155 - Cap. Soc. € 113.190.480,00 I.V. - info@beltrame.it - www.gruppobeltrame.com

Z01 We hereby certify that above mentioned materials have been delivered in accordance with the terms of order.
D01 Surface control and dimensional check = satisfactory
C42 and C43 recalculated Impact test results respect to 10x10 standard section

bsi ISO 9001 Quality Management Systems CERTIFIED

Cast/Heat No: BE 209505 Mill Ref: Certificate Ref: 405660

This is a true copy of the test certificate

Page 1 of 3

UK CA

IMS
INDUSTRIAL METAL SERVICES
Metalstock House, Vanguard Way.
Shoeburyness, Southend-on-Sea, Essex SS3 9RE
Registered No. SC030987 VAT No. GB723932239

MATERIAL CERTIFICATE
Customer: SFWR LTD
Customer Ref:
Sales Order no: 483926.02
Despatch No:
Product: SQUARE 10mm MILD STEEL SI
Size: 6.100 x 10.000
Quantity: 10
Delivery Date: 15/09/23

More than Steel
Tel: 01702 296955
Fax: 01702 296444
sales@industrialmetal.co.uk
www.industrialmetal.co.uk

40+40+3 Box
STANCHIONS

UNIVERSAL TUBE AND PLASTIC INDUSTRIES LTD.

P.O. BOX 16879, JEBELALI FREE ZONE, DUBAI - U.A.E.
TEL. :009714-8835966 FAX :009714- 8835675

MILL'S TEST CERTIFICATE

EN 10204 TYPE 3.1

F: UTP /QC /21 REV:0

APPLICANT : BRISKO METAL RESOURCES (UK)
UNIT 16, KINGSMILL BUSINESS PARK
CHAPEL MILL LANE, KINSTON UPON THAMES
SURREY KT1 3GZ, ENGLAND U.K

DATE OF ISSUE : 01 / 07 / 23
MTC / BSL / 60886 / 23

MATERIAL :-ERW STEEL PIPES HOLLOW SECTION AS PER EN 10219 GRADE S235JRH IN LENGTH OF 7.50 MTR(-0/ +20MM)

PO NO: BM-LPO1002870

				DIMENSIONS			MECHANICAL ANALYSIS			CHEMICAL ANALYSIS % (MAX)							
SIZE	CATE	QTY.	HEAT	WALL	LENGTH	NDT	YS	UTS	%EL								
	GORY			THICKNESS	METER	ECT	N/MM2	N/MM2	2"G.L	C	MN	S	P	SI	AL	N	CE
MM		PCS	NO	MM													
60 x 30	RHST	576	6862129	3.00	7.50	OK	338	419	32	0.102	0.430	0.010	0.0160	0.006	0.0350	0.003	0.174
40 x 40	SHST	2548	71206	2.50	7.50	OK	364	464	28	0.109	0.630	0.005	0.0130	0.015	0.0330	0.003	0.214
40 x 40	SHST	3185	152226	3.00	7.50	OK	329	437	31	0.126	0.445	0.009	0.0075	0.006	0.0493	0.003	0.200
50 x 50	SHST	2009	152226	2.50	7.50	OK	334	445	30	0.126	0.445	0.009	0.0075	0.006	0.0493	0.003	0.200
50 x 50	SHST	2989	6862129	3.00	7.50	OK	341	427	31	0.102	0.430	0.010	0.0160	0.006	0.0350	0.003	0.174
48.3	CHST	854	133195	4.00	7.50	OK	305	428	32	0.122	0.455	0.006	0.0087	0.007	0.0398	0.005	0.198

YS : YIELD STRENGTH
UTS : ULTIMATE TENSILE STRENGTH
EL : ELONGATION
GL : GAUGE LENGTH
ECT : EDDY CURRENT TEST AS PER EN ISO 10893-2

WE HEREBY CERTIFY THAT THE GOODS DESPATHED HAVE BEEN TESTED IN ACCORDANCE WITH ABOVE SPECIFICATION AND FOUND SATISFACTORY

CE
0045
UNIVERSAL TUBE & PLASTIC INDUSTRIES LTD, P.O. Box No. 16879, Jebel Ali Free Zone, Dubai – UAE.
11
DOP No.: UTP/DOP/001
Certificate No. 0045-CPR-1563

P.O. Box: 16879
Jebel Ali Free Zone
Dubai - U.A.E.
Tel.: 009714 - 8835966
Fax.: 009714 - 8835675
Universal Tube & Plastic Industries Ltd.

SANJEEV PANDEY
QC ENGINEER

Cast/Heat No: 71206 Mill Ref: Certificate Ref: 0045-CPR-1563

This is a true copy of the test certificate

INDUSTRIAL METAL SERVICES
Metalstock House, Vanguard Way,
Shoeburyness, Southend-on-Sea, Essex SS3 9RE
Registered No. SC030987 VAT No. GB723932239

MATERIAL CERTIFICATE

Customer: SFWR LTD
Customer Ref:
Sales Order no: 483926.01
Despatch No:
Product: 40 X 40 X 2.5mm R.H.S. COLD F
Size: 7.500 x 40.000
Quantity: 2
Delivery Date: 15/09/23

More than Steel
Tel: 01702 296955
Fax: 01702 296444
sales@industrialmetal.co.uk
www.industrialmetal.co.uk