From: Ian Stocks <ian.stocks@westsussex.gov.uk> on behalf of FRS Water and Access
Sent: 26 July 2022 14:31
To: planning@adur-worthing.gov.uk
Subject: Hydrant condition consultation - AWDM126722 Seaside Primary School Freshbrook Road Lancing West Sussex

FAO: Peter Barnett

Dear Peter,

Providing the fire hydrant indicated on the plan submitted is in place, ready for use and West Sussex Fire & Rescue Service (WSFRS) are made aware it is available for use prior to the new property being occupied/in use, WSFRS would consider the fire hydrant condition to have been met.

Regards

Ian Stocks

Ian Stocks – Water and Access Manager
Water & Access Office
West Sussex Fire and Rescue Service West Sussex County Council
Location: Bognor Fire Station, West Meads Drive, Bognor, PO21 5TB
Phone: 0330 222 3117 | E-mail: frs.waterandaccess@westsussex.gov.uk

Living Our Values Every Day



LEGAL DISCLAIMER
This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.