from Southern Water

Your ref
AWDM/0943/24

Our ref
DSA000036256

Date
28/08/2024

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Conversion from 2 No. flats (Flat 1 and 2) back into single dwelling house and alterations to provide new doors
Site: Flat 1 135 Brighton Road Worthing West Sussex.

Thank you for your correspondence dated 05/07/2024 regarding the above planning application please see our comments below.

The Council's Building Control officers or technical staff should be asked to comment on the adequacy of soakaways to dispose of surface water from the proposed development. No new soakaways should be located within 5 metres of a public or adoptable gravity sewer, rising main or water main.

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119).

Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,

Future Growth Planning Team
Developer Services
southernwater.co.uk/developing-building/planning-your-development

Southern Water Services Ltd, Registered Office: Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX Registered in England No. 2366670