# WEST SUSSEX COUNTY COUNCIL CONSULTATION

| | |
|---|---|
| **TO:** | Adur & Worthing Councils<br>FAO: Stephen Cantwell |
| **FROM:** | WSCC – Highways Authority |
| **DATE:** | 11 July 2024 |
| **LOCATION:** | Hm Revenues And Customs<br>Barrington Road<br>Worthing<br>West Sussex<br>BN12 4XL |
| **SUBJECT:** | AWDM/1456/23<br>Non-Material Amendment to approved AWDM/0605/22 for relocated substation (between flat blocks B and C) and relocation of parking (overall numbers to stay the same).<br><br>More information received. |
| **DATE OF SITE VISIT:** | n/a |
| **RECOMMENDATION:** | Advice |

WSCC in its role of Local Highway Authority (LHA) has been consulted on the above proposals. These comments follow the LHA's initial comments on this element of the scheme in October 2023.

**Comments**
It is understood that the parking will remain unchanged as a result of these changes. There will however be a change in the turning arrangements. The LHA has reviewed the drawings and is in principle satisfied with the revised arrangement for private cars. It was however suggested that the applicant provides a revised swept path analysis drawing demonstrating that the new arrangement can accommodate moments for a refuse collection vehicle.

The LHA are in receipt of two drawings from the applicant numbers-K43058-ATCN-XX-ZZ-DR-Z-7003 Rev C2 and K43058-ATCN-XX-ZZ-DR-Z-7000 Rev C5.

C2-demonstrates turning for a refuse tender. This includes the whole site and the area requested for further analysis in 2023. Having assessed the drawings, the LHA would be satisfied with the arrangement.

C5-provides the same analysis but this drawing includes a fire tender. The LHA would be satisfied with the level of detail provided within this latest drawing.

**Conclusion**
Having regard for the previous comments and additional information now provided the LHA would not raise any concerns with the application and would be satisfied with the proposed minor material amendments.

**Jamie Brown**
**West Sussex County Council – Planning Services**