Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 17/04/2025 12:08 PM from Mr Oliver Rochford (oliver.rochford@adur-worthing.gov.uk) on behalf of Environmental Health Public Health.

Application Summary

Reference:	AWDM/0319/25
Address:	Premium House 1 The Esplanade Worthing West Sussex
Proposal:	Approval of details reserved by condition 2 (Noise mitigation) of application NOTICE/0007/23
Case Officer:	Louise Prew

Click for further information

Comments Details

Comments:	An internal noise commissioning testing report (Dated:11/03/2025, REF:7488_002M_1-0_JE) was submitted in support of the discharge of Condition 2 of planning application Notice/0007/23. I am satisfied that the report has demonstrated that the noise mitigation methods employed have achieved the criteria laid out in BS:8233:2014. Therefore I am satisfied that Condition 2 has been met and recommend discharge of the relevant condition.