From: Gary Peck
Sent: 29 July 2013 15:10
To: Matthew Porter
Subject: FW: AWDM/0804/13: Smoking Shelter, Royal British Legion.

Matt

This is your application?

Gary

Gary Peck - Planning Services Manager, Development Management | Adur and Worthing Councils
Location: Adur Civic Centre, Ham Road, Shoreham-by-Sea, West Sussex, BN43 6PR
Internal: 63483 | External: 01903 221406 | E-mail: gary.peck@adur-worthing.gov.uk
Follow us on Facebook and Twitter - or search Adur and Worthing

Please think before you print this and save paper

From: Michael Lavender
Sent: 29 July 2013 13:52
To: Gary Peck
Subject: AWDM/0804/13: Smoking Shelter, Royal British Legion.

Hi Gary,

I would object to the application as it stands.

Under the Health Act 2006, it is an offence to allow smoking in an enclosed or substantially enclosed area where the public have access. At least 50% of the wall space must be open in order not to be classed as substantially enclosed. The proposed development does not meet these standards.

Kind Regards

Michael Lavender

Michael Lavender - Senior Environmental Health Officer, Environmental Health | Adur & Worthing Councils
Location: Portland House, Richmond Road, Worthing BN11 1HS
Internal: 81092 | External: 01273 263343 | E-mail: michael.lavender@adur-worthing.gov.uk
Follow us on Facebook and Twitter - or search Adur and Worthing

Please think before you print this and save paper