Development Management - Delegated Officer Report

Application Number: AWDM/1408/23 Recommendation – APPROVE

Site: 134 Old Shoreham Road, Shoreham-by-Sea, BN43 5TE

Proposal: Application for a Lawful Development Certificate for proposed rooms in roof consisting of rear dormer with Juliet balcony and front rooflight. Added roof lights to existing single storey extension.

Date of site visit: Assessment has also been assisted using the Applicants plan; Earthlight mapping; and Google 3D of the site

Neighbours checked: Y

Additional neighbour notifications: N

Site and Surroundings:

The application site is positioned on the east side of Old Shoreham Road, Shoreham, and is a middle of terrace, two storey dwelling. The property has a rear extension across the full width of the dwelling, and it also has a long rear garden which abuts a rear access road to garages to the properties on this section of Old Shoreham Road and also serves garages to the rear of Connaught Avenue being the road to the rear of Old Shoreham Road.

Many properties within this section of Old Shoreham Road and locality have extended in some form, including rear extensions and roof dormers.

The site is not a Listed Building or within a Conservation Area.

Relevant Planning History:

SU/25/06/T Single storey rear extension and rooms in the roof with 2 pitched roof rear dormers. **Approved 30.03.2004**

Proposal:

A Certificate of Lawfulness is sought for a:-

- A flat roof rear dormer with rear window a glazed French doors with Juliet balcony;
- 1no. rooflight to the front roofslope;
- 3no. rooflights to the roof of the existing single storey rear extension; and
- Replace French doors and window on existing rear extension with full glazed bifold doors

Planning Assessment

Principle

The proposal will be viewed against the criteria of permitted development as laid out within The Town and Country Planning (General Permitted Development) (England) Order 2015 as amended

Consideration

Schedule 2, Part 1, Development within the curtilage of a dwellinghouse.

Class A – enlargement, improvement or other alteration of a dwellinghouse

Permitted Development

A.The enlargement, improvement or other alteration of a dwellinghouse.

Development not permitted

A.1 Development is not permitted by Class A if—

(a) permission to use the dwellinghouse as a dwellinghouse has been granted only by virtue of Class G, M, MA, N, P, PA or Q of Part 3 of this Schedule (changes of use);

Analysis: The above does not apply

(b) as a result of the works, the total area of ground covered by buildings within the curtilage of the dwellinghouse (other than the original dwellinghouse) would exceed 50% of the total area of the curtilage (excluding the ground area of the original dwellinghouse);

Analysis: Does not apply as no ground floor extension proposed.

(c) the height of the part of the dwellinghouse enlarged, improved or altered would exceed the height of the highest part of the roof of the existing dwellinghouse;

Analysis: The 3no. rooflights within the existing ground floor rear extension will not exceed the height of the highest part of the roof of the existing dwellinghouse, nor will the 1no. rooflight within the front roofslope of the main house.

(d) the height of the eaves of the part of the dwellinghouse enlarged, improved or altered would exceed the height of the eaves of the existing dwellinghouse;

Analysis: Does not apply as no ground floor extension proposed.

(e) the enlarged part of the dwellinghouse would extend beyond a wall which—

(i) forms the principal elevation of the original dwellinghouse; or
(ii) fronts a highway and forms a side elevation of the original dwellinghouse;

Analysis: Does not apply as no enlargement proposed.

(f) subject to paragraph (g), the enlarged part of the dwellinghouse would have a single storey and—

(i) extend beyond the rear wall of the original dwellinghouse by more than 4 metres in the case of a detached dwellinghouse, or 3 metres in the case of any other dwellinghouse, or
(ii) exceed 4 metres in height;

Analysis: Does not apply as no enlargement proposed.

(g) for a dwellinghouse not on article 2(3) land nor on a site of special scientific interest, the enlarged part of the dwellinghouse would have a single storey and—
(i) extend beyond the rear wall of the original dwellinghouse by more than 8 metres in the case of a detached dwellinghouse, or 6 metres in the case of any other dwellinghouse, or
(ii) exceed 4 metres in height;

Analysis: Does not apply

(h) the enlarged part of the dwellinghouse would have more than a single storey and—

(i) extend beyond the rear wall of the original dwellinghouse by more than 3 metres, or
(ii) be within 7 metres of any boundary of the curtilage of the dwellinghouse being enlarged which is opposite the rear wall of that dwellinghouse;

Analysis: Does not apply.

(i) the enlarged part of the dwellinghouse would be within 2 metres of the boundary of the curtilage of the dwellinghouse, and the height of the eaves of the enlarged part would exceed 3 metres;

Analysis: Does not apply.

(j) the enlarged part of the dwellinghouse would extend beyond a wall forming a side elevation of the original dwellinghouse, and would—

(i) exceed 4 metres in height,
(ii) have more than a single storey, or
(iii) have a width greater than half the width of the original dwellinghouse; or

Analysis: Does not apply, as no enlargement of the ground floor is proposed.

(ja) any total enlargement (being the enlarged part together with any existing enlargement of the original dwellinghouse to which it will be joined) exceeds or would exceed the limits set out in sub-paragraphs (e) to (j);

Analysis: Does not apply.

(k) it would consist of or include—

(i) the construction or provision of a verandah, balcony or raised platform,
(ii) the installation, alteration or replacement of a microwave antenna,
(iii) the installation, alteration or replacement of a chimney, flue or soil and vent pipe, or
(iv) an alteration to any part of the roof of the dwellinghouse.

Analysis: There will be an alteration to the roof of the main house which is covered by Class B and C below.

A.2 In the case of a dwellinghouse on article 2(3) land, development is not permitted by Class A if—

(a) it would consist of or include the cladding of any part of the exterior of the dwellinghouse with stone, artificial stone, pebble dash, render, timber, plastic or tiles;

(b) the enlarged part of the dwellinghouse would extend beyond a wall forming a side elevation of the original dwellinghouse; or

(c) the enlarged part of the dwellinghouse would have more than a single storey and extend beyond the rear wall of the original dwellinghouse.

(d) any total enlargement (being the enlarged part together with any existing enlargement of the original dwellinghouse to which it will be joined) exceeds or would exceed the limits set out in sub-paragraphs (b) and (c).

Analysis: The site is not on article 2(3) land

Conditions

A.3 Development is permitted by Class A subject to the following conditions—

(a) the materials used in any exterior work (other than materials used in the construction of a conservatory) must be of a similar appearance to those used in the construction of the exterior of the existing dwellinghouse;

Analysis: The plans are notated to state materials will match the existing;

(b) any upper-floor window located in a wall or roof slope forming a side elevation of the dwellinghouse must be—

(i) obscure-glazed, and

(ii) non-opening unless the parts of the window which can be opened are more than 1.7 metres above the floor of the room in which the window is installed; and

Analysis: Does not apply.

c) where the enlarged part of the dwellinghouse has more than a single storey, or forms an upper storey on an existing enlargement of the original dwellinghouse, the roof pitch of the enlarged part must, so far as practicable, be the same as the roof pitch of the original dwellinghouse.

Analysis: None of the above applies.

Class B – additions etc. to the roof of a dwellinghouse

Permitted Development

B The enlargement of a dwellinghouse consisting of an addition or alteration to its roof

Development not permitted

B.1 Development is not permitted by Class B if:-

a) The dwellinghouse has been granted only by virtue of Class G, M, MA, N, P, PA or Q.

Analysis: The dwellinghouse has not been created through change of use by virtue of Part 3.

b) The height of the roof extension would exceed the highest part of the existing roof;

Analysis: The flat roof of the rear dormer is below the highest part (ridge) of the existing roof.

(c) the roof extension would extend beyond the plane of any existing roof slope which forms the principal elevation of the dwellinghouse and fronts a highway;

Analysis: The rear dormer will not be onto the principal elevation etc.

(d) the cubic content of the resulting roofspace would exceed the cubic content of the original roof by more than:-
i) 40 cubic metres in the case of a terrace house, or
ii) 50 cubic metres in any other case.

Analysis: The submitted plan dormer plan has been notated with the dimensions, being 3.296 (depth) x 5.325 (width) x 2.495(height) = (43.8)/2 = 21.9m^3 The total cubic capacity is thereby less than 40 m^3 .

(e) it would consist of or include:-
i) the construction or provision of a verandah, balcony or raised platform, or
ii) the installation, alteration or replacement of a chimney, flue or soil and vent pipe;

Analysis: There will be a Juliet balcony, but that is not a balcony, only a guard.

(f) the dwellinghouse is on article 2(3) land

Analysis: The dwelling house is not on article 2(3) land.

(g) the dwellinghouse is built under Part 20 of this Schedule (construction of new dwellinghouses); or

Analysis: The dwellinghouse has not been created by virtue of Part 20.

(h) the existing dwellinghouse has been enlarged in reliance on the permission granted by Class AA (enlargement of a dwellinghouse by construction of additional storeys).

Analysis: The above does not apply.

Condtions

B.2 Development is permitted subject to the following conditions:-

(a) the materials used in any exterior work must be of similar appearance to those used in the construction of the exterior of the existing house;

Analysis: The submitted plans are notated stating “All Loft Materials to Match Existing’.

(b) the enlargement must be constructed so that:-

i) other than in the case of a hip-to-gable enlargement which joins the original roof to the roof of a rear or side extension –

(aa) the eaves of the original roof are maintained or reinstated; and

(bb) the edge of the enlargement closest to the eaves of the original roof is, so far as practicable, not less than 0.2m from the eaves, measured along the roof slope from the outside edge of the eaves, and

ii) other than in the case of an enlargement which joins the original roof to the roof of a rear or side extension no part of the enlargement extends beyond the outside face of any external wall of the original dwelling house.

Analysis: The proposal complies with the above.

c) any window inserted on a wall or roof slope forming a side elevation of the dwelling house must be:-

i) obscure glazed and
ii) non-opening unless the parts of the window which can be opened are more than 1.7m above the floor of the room in which the window is installed.

Analysis: There is no new window shown to be included within the side of the dormer.

Class C – other alterations to the roof of a dwellinghouse

Permitted development

C. Any other alteration to the roof of a dwellinghouse.

Development not permitted

C.1 Development is not permitted by Class C if—

(a) permission to use the dwellinghouse as a dwellinghouse has been granted only by virtue of Class G, M, MA, N, P, PA or Q of Part 3 of this Schedule (changes of use);

Analysis: The dwellinghouse has not been created through change of use by virtue of Part 3.

(b) The alteration would protrude more than 0.15 metres beyond the plane of the slope of the original roof when measured from the perpendicular with the external surface of the original roof;

Analysis: The submitted plan has been notated and states that:- 'All Roof Lights Will Protrude No More Than 150mm. There are 3no. rooflights within the ground floor and 1no. rooflight on the front roofslope of the main house.

(c) It would result in the highest part of the alteration being higher than the highest part of the original roof;

Analysis: The rooflights etc., will not be higher than the highest part of the original roof, namely the ridge.

(d) It would consist of or include—

(i) the installation, alteration or replacement of a chimney, flue or soil and vent pipe, or

(ii) the installation, alteration or replacement of solar photovoltaics or solar thermal equipment.

Analysis: None of the above are shown on the submitted plans

(e) the dwellinghouse is built under Part 20 of this Schedule (construction of new dwellinghouses).

Analysis: The above does not apply

Conditions

C.2 Development is permitted by Class C subject to the condition that any window located on a roof slope forming a side elevation of the dwellinghouse must be— (a) obscure-glazed; and (b) non-opening unless the parts of the window which can be opened are more than 1.7 metres above the floor of the room in which the window is installed.

Analysis: There is no new window shown to be included within the side elevation of the dormer, and as a terrace there is no other side elevation.

Recommendation

Issue a Certificate of Lawfulness as the proposal is permitted development by Class A; Class B; and Class C within Schedule 2 Part 1 of Town and Country Planning (General Permitted Development) (England) Order 2015 as amended.

Reasons for Recommendation

The proposal constitutes 'development' as defined by Section 55 of the Town and Country Planning Act 1990, and is permitted by Class A; Class B; and Class C of Schedule 2, Part 1 of the Town and Country Planning (General Permitted Development) (England) Order 2015, as amended.

Case Officer: Eve Hearsey Date: 17.01.2024

Authorised by: Peter Barnett Date: 17 January 2024