From: **Richard Small** <richard.small@adur-worthing.gov.uk>
Date: Thu, 27 Jun 2024 at 13:49
Subject: Re: AWDM/0659/24 Beach House gas pipe
To: Louise Prew <louise.prew@adur-worthing.gov.uk>

Hi Louise,

I did correspond with the applicant prior to submission, and looked at the gas pipe route. I felt that the approach adopted was acceptable. I would suggest that the painting of the pipework externally is conditioned to ensure it is painted.

Richard

On Wed, 26 Jun 2024 at 11:37, Louise Prew <louise.prew@adur-worthing.gov.uk> wrote:
Hi Richard,

This application has now been validated. Can you please let me know if you have any comments

Thanks
Louise

Louise Prew
Principal planning officer (Team leader), Planning Services
01903 221155
Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA
www.adur-worthing.gov.uk