From: Michael Lavender <michael.lavender@adur-worthing.gov.uk> on behalf of Michael Lavender
Sent: 19 January 2023 10:37
To: Peter Barnett
Subject: AWDM/2021/22: 114 Od Fort Road.

Hi Peter,

The ASHP positioning looks ok, 4m from the boundary and a further 10m from the nearest neighbouring window.

I am happy with the remediation strategy, we will just need to see the validation report once complete.

Kind Regards

--

Michael Lavender
Senior Environmental Health Officer, Public Health & Regulation
01273 263343
Adur & Worthing Councils
Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA
Environmental Health



