



Adur & Worthing Council
Portland House
44 Richmond Road
Worthing
West Sussex
BN11 1HS

Your ref
AWDM/0810/26

Our ref
DSA000055866

Date
17th July 2026

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: New development comprising the erection of 10 no. dwellings following the demolition of existing agricultural barns

Site address: Land And Barns New Salts Farm New Salts Farm Road Lancing

Thank you for your correspondence, please see our comments below regarding the above application

Proposed works involve demolition:

In order to protect and safeguard the existing water supply apparatus, Southern Water requests formal notification of any proposed demolition works prior to such works being undertaken.

Proposed Development located in Flood plain:

From the site location, it appears that the proposed development lies within an area identified as flood zone 2/3. Southern Water supports the Government's requirement to apply the sequential and exception tests to development sites located in flood zones 2 or 3. In flood events, additional surface water can inundate sewers, which may result in the overloading of the sewerage system. Southern Water will rely on the Council's consultations with the Environment Agency to ensure that any proposed development on a floodplain is appropriately assessed, and necessary mitigation measures adopted.

As this site is in a high risk flood zone the new foul drainage system must be resilient to the flooding as we do not want flood waters to enter the system which would then impede foul drainage from this area and potentially downstream. The developer must ensure the new foul system draining the development does not create a new low spot on the network. If this is a possibility then consideration should be given to having a pumped connection or other satisfactory mitigation. It appears the area is also prone to high groundwater. The new system must be constructed to withstand high groundwater and should be watertight at pipe joints; within manholes and at ground level. The integrity of the system with respect to water tightness must be demonstrated by air testing.

Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX
southernwater.co.uk

Southern Water Services Ltd, Registered Office: Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX Registered in England No. 2366670

Condition:

In view of the risk of inundation of the proposed drainage system, Southern Water would request that the consent is subject to the following condition: The proposed drainage system shall be designed and constructed to prevent the ingress of flood water into the sewerage network.

Proposed SUDS features:

If it is the intention of the developer for Southern Water to adopt the proposed SuDS, the system shall be designed and constructed in line with the Design and Construction Guidance www.water.org.uk/sewerage-sector-guidance-approved-documents/.

No Soakaways should be connected to the public surface water sewer.

Existing Water Main - tree, buildings, assets within stand-off distance:

The 200 mm diameter water main requires a clearance of 3 metres on either side of the water main to protect it from construction works and to allow for future maintenance access.

No excavation, mounding or tree planting should be carried out within 3 metres of the external edge of the public water main without consent from Southern Water. All existing infrastructure, including protective coatings and cathodic protection, should be protected during the course of construction works. Please refer to: <https://www.southernwater.co.uk/media/st5orjvm/stand-off-distances.pdf>

Condition:

In order to protect water apparatus, Southern Water requests that if consent is granted, the following condition is attached to the planning permission; The developer must agree with Southern Water, prior to commencement of the development, the measures to be undertaken to protect/divert the public water supply main.

Sewer abandon / Diversion by Developer:

Please find attached an extract of Southern Water records showing the approximate position of a public sewer/water main crossing the site.

It appears that the applicant is proposing to abandon/divert a Southern Water asset (Water Main or Sewer). Any public diversion proposals shall be approved by Southern Water under Section 185 of the Water Industry Act. An application should be made using Southern Water's Get Connected Service at <https://developerservices.southernwater.co.uk>

Connection to public sewer - capacity available desktop study under 50:

Southern Water has undertaken a desktop study of the area, and our investigations indicate that Southern Water can facilitate foul sewerage /surface water run off disposal to service the proposed development. Southern Water requires a formal application for a connection to the public sewer to be made by the applicant or developer.

To make an application visit Southern Water's Get Connected service:

<https://developerservices.southernwater.co.uk> and please read our New Connections Charging Arrangements documents which are available on our website via the following link: <https://www.southernwater.co.uk/developing-building/connection-charging-arrangements>



We request that should this planning application receive planning approval, the following informative is attached to the consent: Construction of the development shall not commence until details of the proposed means of foul sewerage and surface water disposal have been submitted to, and approved in writing by the Local Planning Authority in consultation with Southern Water.

Connection to water distribution main:

Our investigations indicate that Southern Water can facilitate water supply to service the proposed development. Southern Water requires a formal application for a connection to the water supply to be made by the applicant or developer.

To make an application visit Southern Water's Get Connected service:

<https://developerservices.southernwater.co.uk> and please read our New Connections Charging Arrangements documents which are available to read on our website via the following link www.southernwater.co.uk/developing-building/connection-charging-arrangements

It is possible that a sewer now deemed to be public could be crossing the development site. Therefore, should any sewer be found during construction works, an investigation of the sewer will be required to ascertain its ownership before any further works commence on site. If this happens, please call our Customer Service Desk on 0330 303 0119.

For further assistance, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (TEL: 0330 303 0119)

Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,

Future Growth Planning Team
Developer Services

Southernwater.co.uk/developing-building/planning-your-development