-------- Forwarded message ---------
From: **FRS Water and Access** <FRSWaterandAccess@westsussex.gov.uk>
Date: Thu, 16 Jul 2020 at 13:44
Subject: RE: AWDM/0634/20 Land South Of 35 To 37 High Street Shoreham-By-Sea West Sussex
To: dawn.anthony-unsted@adur-worthing.gov.uk <dawn.anthony-unsted@adur-worthing.gov.uk>

Dear Dawn,

Having viewed the relevant documents for 35 To 37 High Street Shoreham-By-Sea West Sussex - planning application number AWDM/0634/20 I am satisfied there is adequate supply of water for firefighting (fire hydrant within 40 metres) and suitable access for a fire appliance. Therefore West Sussex Fire & Rescue Service water & Access department are satisfied with this planning application.

Regards

Ian Stocks
Water & Access manager.

Water and Access Office
West Sussex Fire and Rescue Service West Sussex County Council
Location: Bognor Fire Station, West Meads Drive, Bognor, PO21 5TB
Phone: 0330 222 3117 | E-mail: frs.waterandaccess@westsussex.gov.uk

Living Our Values Every Day

