From: planning@adur-worthing.gov.uk
Sent: 25 October 2021 12:05
To: planning@adur-worthing.gov.uk
Subject: Consultee Comments for Planning Application AWDM/1788/21

Flag Status: Flagged

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 25/10/2021 12:05 PM from Mrs Hannah Powell (hannah.powell@adur-worthing.gov.uk) on behalf of Environmental Health Public Health.

Application Summary

Reference:	AWDM/1788/21
Address:	20 North Road Lancing West Sussex BN15 9AE
Proposal:	Approval of Details Reserved by Condition 3 (extraction equipment) and 4 (sound insulation) of Application AWDM/0776/20.
Case Officer:	Marie O'Keeffe

Click for further information

Comments Details

Comments:	With reference to the above application to discharge conditions 3 and 4 of AWDM/0776/20: Condition 3 Further information is required (please see Adur and Worthing Council's Kitchen Extraction and Ventilation – Information & Guidance2019): Please confirm whether gas or electric will be used for cooking Please confirm the height of the stack above eaves (this should be at least 1m) Please provide a schematic plan of kitchen ventilation system showing position of the canopy/grease filter over cooking area as well as the position of the other abatement, fan and flue. Specification of fan should be provided (including noise levels) and confirmation that it is a variable speed fan. The frequency of carbon filter change is not specified. Condition 4 The noise tests demonstrate that the insulation between the two units is acceptable. I can recommend the discharge of this condition.

Kind regards