

Development Management - Delegated Officer Report

Application Number: AWDM/0515/26

Recommendation – Approve

Site: 60 Greet Road, Lancing, West Sussex

Proposal: Application for Certificate of Lawfulness for 2 no. proposed rear dormers.

Date of site visit: No visit

Planning Assessment

Principle

The application site is an end of terrace chalet bungalow. A loft conversion has already been carried out with a hip to part gable side extension with front and rear roof lights.

2. no. flat roof rear dormers are proposed.

The site is not within a Conservation Area and is not a Listed Building.

The proposal will be viewed against the criteria of permitted development, as laid out within The Town and Country Planning (General Permitted Development) (England) Order 2015

Consideration

Schedule 2, Part 1, Development within the curtilage of a dwellinghouse
Permitted Development

Class B The enlargement of a dwellinghouse consisting of an addition or alteration to its roof

B.1 Development is not permitted by Class B if:

a) The dwellinghouse has been granted only by virtue of Class M, N, P, PA or Q.

Analysis: N/A

b) The height of the roof extension would exceed the highest part of the existing roof;

Analysis: The proposed dormers do not exceed the height of the existing ridge.

(c) the roof extension would extend beyond the plane of any existing roof slope which forms the principal elevation of the dwelling house and fronts a highway;

Analysis: The proposed dormers are to the rear of the building.

(d) the cubic content of the resulting roofspace would exceed the cubic content of the original roof by more than:-

- i) 40 cubic metres in the case of a terrace house, or
- ii) 50 cubic metres in any other case.

Analysis: The plans state that the existing hip to half gable extension added 20.3 cubic metres, the proposed dormers add a further 8.55 cubic metres. In total 28.85 cubic metres. Below the 50 cubic metres permitted here.

(e) it would consist of or include:-

- i) a verandah, balcony or raised platform or
- ii) the installation, alteration or replacement of a chimney, flue or soil and vent pipe;

Analysis: There are none of the above proposed.

(f) the dwellinghouse is on article 2(3) land

Analysis: The development is not in a conservation area

(g) the dwellinghouse is built under Part 20 of this Schedule (construction of new dwellinghouses).

Analysis: N/A

B.2 Development is permitted subject to: -

(a) the materials used in any exterior work must be of similar appearance to those used in the construction of the exterior of the existing house.

Analysis: The supporting document states that materials to be used will match existing.

(b) the enlargement must be constructed so that: -

i) other than in the case of a hip-to-gable enlargement which joins the original roof to the roof of a rear or side extension –

(aa) the eaves of the original roof are maintained or reinstated; and

(bb) the edge of the enlargement closest to the eaves of the original roof is so far as practicable not less than 0.2m from the eaves, measured along the roof slope from the outside edge of the eaves, and

ii) other than in the case of an enlargement which joins the original roof to the roof of a rear or side extension no part of the enlargement extends beyond the outside face of any external wall of the original dwelling house.

Analysis: The eaves are retained and the dormers are set 200mm up from them as shown on the submitted plans and supporting document.

c) any window inserted on a wall or roof slope forming a side elevation of the dwelling house must be:-

- i) obscure glazed and
- ii) non-opening unless the parts of the window which can be opened are more than 1.7m above the floor of the room in which the window is installed.

Analysis: - There is no window on the side gable.

Recommendation

Issue a Certificate of Lawfulness for Proposed Development, the submission of a planning application for the works will not be required.

Reasons for Recommendation

The proposal constitutes 'development' as defined by Section 55 of the Town and Country Planning Act 1990, but is permitted by Class B of Part 1 Schedule 2 of Town and Country Planning (General Permitted Development) (England) Order 2015.

Case Officer:	Hannah Barker	Date: 11th June 2026
Authorised by:	Peter Barnett	Date: 11 June 2026