From: Michael Lavender <michael.lavender@adur-worthing.gov.uk> on behalf of Michael Lavender
Sent: 28 September 2021 11:40
To: Peter Barnett
Subject: AWDM/1415/21: Joyful Whippet

Flag Status: Flagged

Hi Peter,

I am sorry for the delay in responding to this one.

the 6.8mm Acoustic laminate glass should be sufficient for noise control, but I am not happy with the chosen ventilation.

According to the product information this vent is located in the loft and blows filtered air through the ceiling. I know from experience that my loft space becomes unbearably hot during the summer and this system is going to be blowing this heated air into the habitable rooms during the summer months. As windows need to be kept closed because of road noise these rooms are at risk of overheating if this ventilation is used. See link below.
https://www.nuaire.co.uk/product-list-page/drimaster-eco-range

I would be more inclined to use the Titan Sonair F as this is a wall mounted vent that will allow cooler external air to be brought into the rooms during summer months and can be turned off during winter months where it will act as a passive ventilation system.

Regards

Michael Lavender
Senior Environmental Health Officer, Adur & Worthing Councils
Phone: 01273 263343
Email: michael.lavender@adur-worthing.gov.uk
Website: Environmental Health
Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA

