--------- Forwarded message ---------
From: **Michael Lavender** <michael.lavender@adur-worthing.gov.uk>
Date: Tue, 18 Mar 2025 at 15:52
Subject: AWDM/1549/24: 37 Windsor Road
To: Finlay Gardner <finlay.gardner@adur-worthing.gov.uk>

Hi Finlay,

I have looked at this application again now the additional information has been provided and I can confirm there are no EH objections to this ASHP being positioned in this location.

ASHP's are used for heating and hot water. During the summer when people are outside enjoying the garden, the heating is not on, and typically these units will only run for a few hours to provide hot water. It's also worth noting that they work by stripping the heat from the outside air, therefore they will not need to work so hard during the warmer summer months as they would for the colder winter months as the outside air is warmer. Combine this with the fact that the unit will be around 25m from the boundary with the property on Gannon Road, I do not expect noise from this unit will be a problem to these neighbours.

KInd Regards

Michael Lavender
Senior Environmental Health Officer, Public Health & Regulation
01273 263343
Adur & Worthing Councils
Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA
Environmental Health



