From: Louise Prew <louise.prew@adur-worthing.gov.uk>
Sent: 07 March 2024 14:14:10 UTC+00:00
To: "Emily Drake-Julnes" <emily.drake-julnes@adur-worthing.gov.uk>
Subject: Fwd: AWDM/0205/24: Worthing Hospital

Hi,

Can you please upload this as an EH comment

Thanks

---------- Forwarded message ---------
From: **Michael Lavender** <michael.lavender@adur-worthing.gov.uk>
Date: Wed, 21 Feb 2024 at 16:20
Subject: AWDM/0205/24: Worthing Hospital
To: Louise Prew <louise.prew@adur-worthing.gov.uk>

Ho Louise,

There are no EH objections in principle but the applicant should be aware that if you exhaust gas under pressure through long lengths of pipework, that it can sometimes create a hum and if this is the case then a silencer may need to be fitted to the flue outlet.

Regards

Michael Lavender
Senior Environmental Health Officer, Public Health & Regulation
01273 263343
Adur & Worthing Councils
Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA
Environmental Health



