

Fire Hydrant Plan

1 : 200

Notes

Do not scale from this drawing. All dimensions to be verified by the contractor on site.

FIRE STRATEGY KEY

FIRE DOOR RATING

- Fire Door with smoke seal
- 30mins Fire
- 60mins Fire

WALL FIRE RATING

Walls to achieve minimum fire resistance and integrity for compartmentation.

- 60mins Fire Resistance
- 30mins Fire Resistance

FIRE ESCAPE ROUTE

A - "Length"

FE — Final Exit.

SMOKE CONTROL SOLUTIONS

- OV — Opening Vent
- AOV — Automatic Opening Vent.

SPECIAL EQUIPMENT

- FH - "Length" — Indicates fire hose travel distances from either pumped appliance or dry riser outlet. Hose length not to exceed 45m as approved document Part B
- Outlet — Indicates location of dry riser outlet locations.
- Indicates indicative dry riser horizontal pipe runs to outlets. Pipework to be installed as per M&E design and specifications.
- Inlet — Indicates location of dry riser inlet locations. Inlets to be located max 18m from final fire tender location.

Additional informatrion on Sheet 0000 - Notes & Abbreviations

This drawing is to be read in conjunction with the latest Fire Strategy prepared in connection with this project.

Key Plan

As indicated@A1

North Point

Rev	Description	Date	Init	Chkd

Project

The Mannings, Shoreham-By-Sea

Title

Fire Hydrant Plan

Client

Real LSE Ltd

Status

Preliminary

Date	Drawn By	Checked By
01.03.2023	P.D.H.	K.A.

Project No.	Drawing No.	Revision
K210031-	RL51001- CAL- XX- GF- PL- A-0911	

Stewart Court 214a Hagley Road Edgbaston Birmingham B16 9PH
01214 541688 birmingham@calfordseaden.com calfordseaden.com
calfordseaden LLP is a Limited Liability Partnership Registered in England & Wales number OC315838
LONDON ▮ BIRMINGHAM ▮ CAMBRIDGE ▮ KENT ▮ ESSEX ▮ HAMPSHIRE