From: **Michael Lavender** <michael.lavender@adur-worthing.gov.uk>
Date: Wed, 30 Sept 2026 at 11:59
Subject: Worthing Energy Centre
To: Louise Prew <louise.prew@adur-worthing.gov.uk>

Hi Louise,

Will this work for you? The original acoustic report set plant noise criterion at the nearest residential receptors,it is this criterion that we are checking has been achieved.

Within 35 days from the date of this permission, the KP Acoustic Report, Reference 26677.PCR.01 dated 12/10/23 which was submitted with Application AWDM/1439/23, shall be updated to take into account the revised position of the plant, the specific details of the chosen product, and any additional noise mitigation. Thereafter, this updated report shall be submitted to the local planning authority in writing for approval to demonstrate that the original noise objectives have been achieved. In the event that the original noise objectives have not been achieved, then notwithstanding the installation of the plant hereby approved, the air source heat pumps shall not be used until a further scheme of attenuation works capable of achieving the objectives as specified have been submitted and agreed in writing by the Local Planning Authority. Following installation, the Air Source Heat Pumps, acoustic barrier, and any further attenuation measures as may be agreed, shall be retained for the lifetime of the development and maintained in accordance with the manufacturer's recommendations.

{\b Reason}: {\i To safeguard the amenities of nearby residential occupiers and to comply with policies DM5 and DM22 of the Worthing Local Plan and the NPPF.}

Regards

--

Michael Lavender

Senior Environmental Health Officer

01273 263343

Environmental Health
Adur & Worthing Councils

Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA

For details on how we handle your data, please see our Privacy Notice.

https://www.adur-worthing.gov.uk/environmental-health/privacy-notice/