



Adur & Worthing Council
Portland House
44 Richmond Road
Worthing
West Sussex
BN11 1HS

Your ref
AWDM/0265/26

Our ref
DSA000052097

Date
26th March 2026

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Change of use from light industrial (Class E(g)(iii)) to brewery and taproom (Sui Generis); including external chiller units, cycle parking, and a toilet block.

Site: Land At And Site Of Unit 5 And Unit 6, Dominion Trade Centre, Dominion Way, West Worthing, BN14 8NT.

Thank you for your correspondence, please see our comments below regarding the above application.

Insufficient Information provided

Condition

Construction of the development shall not commence until details of the proposed means of foul/surface water drainage disposal have been submitted to, and approved in writing by the Local Planning Authority in consultation with Southern Water.

Trade Effluent – General

Trade effluent is any process liquid waste (effluent) discharged into our sewers from a business or industrial process. This includes any waste water derived from a production process or from washing down or cooling activities including wastes from public funded activities such as municipal landfills. This can be best described as anything other than domestic sewage (toilet, bath or sink waste) or uncontaminated surface water and roof drainage (rainwater).

<https://www.southernwater.co.uk/retail/trade-effluent-retailer>

Trade effluent - non household

To apply for a Consent, you will need to engage a Retailer and submit the application through them.

Southern Water, the wholesaler, is responsible for the assets into which the effluent is discharged and treated. Your chosen retailer will be responsible for all administrative and billing matters.

Attached is a link to the Open Water website that lists Retailers available. Please note that not all Retailers will provide a Trade Effluent service. www.open-water.org.uk/for-customers/find-a-retailer/suppliers/english-water-and-wastewater-retailers

Once we have received an application via your appointed retailer, we have 43 business days to issue a Consent or refuse the application. Southern Water is only responsible for dealing with applications for discharges directly to the foul sewer. Any requirement to discharge directly to the environment will require a permit/consent from the Environment Agency.

Fats Oils and Grease (FOG): Grease Traps

The applicant should be advised that a wastewater grease trap should be provided on the kitchen waste pipe or drain installed and maintained by the owner or operator of the premises.

It should be noted that under the Water Industry Act 1991 it is an offence to "throw, empty, turn or permit to be thrown or emptied or to pass into any drain or sewer connecting with a public sewer... any matter likely to injure the sewer or drain or to interfere with the free flow of its contents."

S106 Connection application

Any new connections to the public sewerage system will require a Section 106 connection application to be submitted and approved by Southern Water Services.

To make an application visit Southern Water's Get Connected service:

<https://developerservices.southernwater.co.uk> and please read our New Connections Charging Arrangements documents which are available on our website via the following link:

<https://www.southernwater.co.uk/developing-building/connection-charging-arrangements>

Please note that, where there are separate systems available Southern Water will not allow surface water to connect into the public foul sewer. If this is not possible, please provide evidence that all other options have been explored.

We request that should this planning application receive planning approval, the following informative is attached to the consent:

Construction of the development shall not commence until details of the proposed means of foul sewerage and surface water disposal have been submitted to and approved in writing by the Local Planning Authority in consultation with Southern Water.

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119)

Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,

Future Growth Planning Team



southernwater.co.uk/developing-building/planning-your-development