Development Control – Delegated Officer Report

Application Number: AWDM/0913/23 Recommendation – APPROVE

Site: 41 Overmead, Shoreham-by-Sea, BN43 5NS

Proposal: Application for a Certificate of Lawfulness for a proposed conversion and extensions of the existing roof space to habitable space by means of the construction of a dormer window on the rear of the existing roof together with 3no. rooflights on the front roof.

Site visit: N/A

Site and Surroundings:

No. 41 Overmead is located on the north side of the road, and is a two storey end of terrace dwelling with a limited rear garden and a large side garden. The dwelling backs onto a road leading to the New Shoreham Burial Ground.

The neighbouring property, no. 40, has an existing rear dormer. Other properties within Overmead have been extended to the rear and to the roof.

The site is not within a Conservation Area and is not a Listed Building.

Proposal

A Certificate of Lawful Development is sought for a proposed loft conversion incorporating a rear dormer and 3no. front rooflights.

Planning Assessment

Principle

The proposal will be viewed against the criteria of permitted development, as laid out within The Town and Country Planning (General Permitted Development) (England) Order 2015 as amended.

Consideration

Schedule 2, Part 1, Development within the curtilage of a dwellinghouse.

Class B – additions etc. to the roof of a dwellinghouse

Permitted Development

B The enlargement of a dwellinghouse consisting of an addition or alteration to its roof

Development not permitted

B.1 Development is not permitted by Class B if:-

a) The dwellinghouse has been granted only by virtue of Class G, M, MA, N, P, PA or Q of Part 3 of this Schedule (changes of use)

Analysis: The dwellinghouse has not been created through change of use by virtue of Part 3.

b) The height of the roof extension would exceed the highest part of the existing roof;

Analysis: The height of the flat roof of the rear dormer is below the highest part of the existing roof.

(c) the roof extension would extend beyond the plane of any existing roof slope which forms the principal elevation of the dwellinghouse and fronts a highway;

Analysis: the roof extension (dormer) will face a driveway leading to the burial grounds (not thought to be a highway for the purposes of this application), and it is not the principal elevation of the dwellinghouse, therefore the above does not apply.

(d) the cubic content of the resulting roofspace would exceed the cubic content of the original roofspace by more than:-
i) 40 cubic metres in the case of a terrace house, or
ii) 50 cubic metres in any other case.

Analysis: A volume calculation has been notated on the submitted plans and shows that the cubic capacity content for the dormer would not exceed the allowed 40m^3

(e) it would consist of or include:-
i) the construction or provision of a verandah, balcony or raised platform, or
ii) the installation, alteration or replacement of a chimney, flue or soil and vent pipe;

Analysis: None shown on the plans.

(f) the dwellinghouse is on article 2(3) land

Analysis: The dwelling house is not on article 2(3) land.

(g) the dwellinghouse is built under Part 20 of this Schedule (construction of new dwellinghouses); or

Analysis: The dwellinghouse has not been created by virtue of Part 20.

(h) the existing dwellinghouse has been enlarged in reliance on the permission granted by Class AA (enlargement of a dwellinghouse by construction of additional storeys).

Analysis: The dwellinghouse has not been enlarged etc. by construction of additional storeys.

B.2 Development is permitted subject to the following conditions:-

(a) the materials used in any exterior work must be of similar appearance to those used in the construction of the exterior of the existing house;

Analysis: The Agent has confirmed in an email dated 04.08.2023 that the tile hanging on the dormer will be to match (or as close too) the existing tiles on the roof.

(b) the enlargement must be constructed so that:-

i) other than in the case of a hip-to-gable enlargement which joins the original roof to the roof of a rear or side extension –

(aa) the eaves of the original roof are maintained or reinstated; and

(bb) the edge of the enlargement closest to the eaves of the original roof is, so far as practicable, not less than 0.2m from the eaves, measured along the roof slope from the outside edge of the eaves, and

ii) other than in the case of an enlargement which joins the original roof to the roof of a rear or side extension no part of the enlargement extends beyond the outside face of any external wall of the original dwelling house.

Analysis: The proposal complies with the above.

c) any window inserted on a wall or roof slope forming a side elevation of the dwelling house must be:-

i) obscure glazed and
ii) non-opening unless the parts of the window which can be opened are more than 1.7m above the floor of the room in which the window is installed.

Analysis: There is no window shown in the wall or roof slope forming a side elevation.

Class C – other alterations to the roof of a dwellinghouse

Permitted development

C. Any other alteration to the roof of a dwellinghouse.

Development not permitted

C.1 Development is not permitted by Class C if—

(a) permission to use the dwellinghouse as a dwellinghouse has been granted only by virtue of Class G, M, MA, N, P, PA or Q of Part 3 of this Schedule (changes of use);

Analysis: The dwellinghouse has not been created through change of use by virtue of Part 3.

(b) The alteration would protrude more than 0.15 metres beyond the plane of the slope of the original roof when measured from the perpendicular with the external surface of the original roof;

Analysis: The agent has confirmed in an email dated 03.08.2023 that the rooflights will not protrude more than 0.15m from the roofslope.

(c) It would result in the highest part of the alteration being higher than the highest part of the original roof;

Analysis: The rooflights etc., will be lower than the ridge and therefore will not be higher than the highest part of the original roof.

(d) It would consist of or include—

(i) the installation, alteration or replacement of a chimney, flue or soil and vent pipe, or

(ii) the installation, alteration or replacement of solar photovoltaics or solar thermal equipment.

Analysis: None of the above applies.

(e) the dwellinghouse is built under Part 20 of this Schedule (construction of new dwellinghouses).

Analysis: The above does not apply

Conditions

C.2 Development is permitted by Class C subject to the condition that any window located on a roof slope forming a side elevation of the dwellinghouse must be— (a) obscure-glazed; and (b) non-opening unless the parts of the window which can be opened are more than 1.7 metres above the floor of the room in which the window is installed.

Analysis: There is no window shown on the side elevation, the proposed rooflights will be on the front roofslope.

Recommendation

Issue a Certificate of Lawfulness as the proposal is permitted development by Class B and Class C within Schedule 2, Part 1 of Town and Country Planning (General Permitted Development) (England) Order 2015 as amended.

Reasons for Recommendation

The proposal constitutes 'development' as defined by Section 55 of the Town and Country Planning Act 1990, and is permitted by Class B and Class C of Schedule 2, Part 1 of the Town and Country Planning (General Permitted Development) (England) Order 2015, as amended

Case Officer: Eve Hearsey Date: 04.08.2023

Authorised by: Peter Barnett Date: 4 August 2023