From: planning@adur-worthing.gov.uk
Sent: 04 August 2023 14:35
To: planning@adur-worthing.gov.uk
Subject: Consultee Comments for Planning Application AWDM/1064/23

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 04/08/2023 2:35 PM from Mr Nadeem Shad (nadeem.shad@adur-worthing.gov.uk) on behalf of Environmental Health Public Health.

Application Summary

Reference:	AWDM/1064/23
Address:	Sea Lane Cafe Marine Crescent Worthing West Sussex BN12 4HR
Proposal:	Proposed aluminium glazed cafe extension to south elevation to replace existing canvas structure, timber framed kitchen extension to west elevation and natural fibre composite cladding to replace existing shiplap cladding
Case Officer:	Amanda Haslett

Click for further information

Comments Details

Comments:	The proposed walk in fridge to the western side of the building will require a compressor to operate. This will create noise so we need to know where the compressor is proposed to be located? We will also need to know the noise created by this, which the supplier should be able to provide. Once in receipt of this information we will be able to comment further.

Kind regards