TOMMY JAMES LTD
Commercial • Industrial • Maintenance

185 Walderslade Road
Chatham
Kent
ME5 0ND
Tel:01634 683368
Fax:01634 683311
mail@tommyjames.co.uk

Dominic Faires
Northgate

25th January 2015

Re: Brighton External Lighting

Hi Dominic,

Please find our proposal for replacement lighting to the front of Northgate Brighton.



Light 1:

The existing light was a 1500W flood light fitting with halogen lamp, mounted at approx 20 degrees with a lumen output: 33000







We would replace this with a lower energy 400w fitting with metal halide lamp that has a lumen output of 38000

We would mount this again between 20 to 30 degrees to give maximum coverage of light to yard.





Light 2:

The existing light has no longer got any identification on it or the lamp. Judging by our experience and matching its size to alternative fittings it would appear to be a 70 watt flood light, mounted at approx 25 degrees. A 70 watt flood light would give an approx lumen reading of 5800





We would replace this with a similar style fitting with 70 watt metal halide lamp that has a lumen output of 5800

We would mount this again between 20 to 30 degrees to give maximum coverage of light to yard.





We hope this information is satisfactory, however should you require additional details please do not hesitate to call.

Yours faithfully,

Vince Gale

EMS 573807 FM 573806 OHS 573808