From: Ian Stocks <ian.stocks@westsussex.gov.uk> on behalf of FRS Water and Access
Sent: 18 May 2022 09:06
To: planning@adur-worthing.gov.uk
Subject: Planning consultation - AWDM/0384/22 Land North Of 1 To 28 The Haven Brighton Road Lancing West Sussex

Flag Status: Flagged

FAO: Peter Barnett

Dear Peter,

Having viewed the plans for the planning application no AWDM/0384/22 for the Construction of 7no. 3 bed dwellings within a terrace of 2 storey buildings with accommodation in the roof space and 14no. parking spaces, 20no. cycle spaces and associated works including landscaping, there is currently a fire hydrant located in close proximity to this intended site. The fire hydrant will need to remain accessible by the Fire Service at all times, if the hydrant is located within the intended property development it will need to be relocated at the cost of the development.

I have attached a screen shot to show the fire hydrant location.

Regards

Ian Stocks



Ian Stocks – Water and Access Manager
Water & Access Office
West Sussex Fire and Rescue Service West Sussex County Council
Location: Bognor Fire Station, West Meads Drive, Bognor, PO21 5TB
Phone: 0330 222 3117 | E-mail: frs.waterandaccess@westsussex.gov.uk

Living Our Values Every Day





LEGAL DISCLAIMER
This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.