From: Bruce Reynolds
Sent: 21 February 2018 17:32
To: Peter Barnett
Subject: AWDM/0212/18 265 Old Shoreham Road Southwick Brighton West Sussex BN42 4LP

Flag Status: Flagged

Dear Peter

The new annex, as set out, has the only means of access to the bedroom through the open plan kitchen/dining room and so it is an inner room. The risk can be mitigated by either creating a lobby for the door to the bedroom, or by ensuring that the bedroom window complies with fire escape window requirements.

Yours sincerely

Bruce Reynolds
Private Sector Housing Manager, Adur & Worthing Councils
Phone: 01273 263098
Email: bruce.reynolds@adur-worthing.gov.uk
Website: www.adur-worthing.gov.uk/adur-homes
Address: Housing, Usually east wing, first floor
Portland House

