From: Michael Lavender <michael.lavender@adur-worthing.gov.uk> on behalf of Michael Lavender
Sent: 08 November 2023 11:29
To: Peter Barnett
Subject: Re: AWDM/1318/23: 94 Brighton Road, Lancing

Flag Status: Flagged

Hi Peter,

The acoustic report is fine and I have no objections subject to the noise mitigation recommended in the report being implemented. I.e the proposed roof construction as assessed, glazing and the MVHR ventilation system recommended in the report .


Regards


Michael Lavender

On Wed, 8 Nov 2023 at 09:49, Peter Barnett <peter.barnett@adur-worthing.gov.uk> wrote:

> Hi Michael
>
> I have now received the noise report. Please can you advise if this is acceptable?
>
> Thanks

Peter Barnett
Principal Planning Officer, Planning & Development
01903 221310
Adur & Worthing Councils
Portland House, 44 Richmond Road, Worthing, BN11 1HS
http://www.adur-worthing.gov.uk







On Tue, 24 Oct 2023 at 13:56, Michael Lavender <michael.lavender@adur-worthing.gov.uk> wrote:

> Hi Peter,
>
> There are no EH objections in principle, but we will need to see an acoustic report for the development setting out the glazing & ventilation strategy. Furthermore, as there is a room in the roof space this will need to be looked at to ensure that there is sufficient noise insulation included in the final design.
>
> Regards

--

Michael Lavender
Senior Environmental Health Officer, Public Health & Regulation
01273 263343
Adur & Worthing Councils
Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA
Environmental Health





--

Michael Lavender
Senior Environmental Health Officer, Public Health & Regulation
01273 263343
Adur & Worthing Councils
Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA
Environmental Health

