Consultee Comments for Planning Application AWDM/1046/24

1 message

planning@adur-worthing.gov.uk <planning@adur-worthing.gov.uk> 5 September 2024 at 18:11
To: planning@adur-worthing.gov.uk

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 05/09/2024 6:11 PM from Mr John Head [redacted] on behalf of The Worthing Society.

Application Summary

Reference:	AWDM/1046/24
Address:	6 Warwick Street Worthing West Sussex BN11 3DL
Proposal:	Internally illuminated Fascia and Projecting signage; applied window vinyls
Case Officer:	Jackie Fox

Click for further information

Comments Details

Comments:	The submitted drawings are not clear about the type of illumination that is proposed. Our understanding from the drawings is that the fascia would not be internally illuminated as it is powder coated aluminium sheet. If we are correct in assuming that it is just the black acrylic letters and logo that would be backlit and that these would be set off from the fascia then we do not have any objection. However, the proposed projecting sign appears to be internally illuminated and this would not be acceptable in the Conservation Area. It would be preferable for this sign not to be illuminated, or possibly to have external illumination by means of spotlights. Please let us know if our interpretation of the drawings is not correct, so that our comments can be revised if necessary.

Kind regards